



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/BP/2026/257

Dated: 25 / 06 / 2026

To

The Chief Architect,
Delhi Metro Rail Corporation Ltd.,
Metro Bhawan, Barakhamba Lane,
Connaught Place, New Delhi - 110001.

**Sub: Examination of building plans from Fire Safety point of view in r/o
Jhandewalan Mandir Metro Station (Underground Metro Station), New Delhi.**

Sir,

Please refer your online request No. DMRC/Fire/204/2026/04/440 dated 30.04.2026, on the subject cited above. In this connection, this is to inform you that the building plans of above-mentioned building have been scrutinized by this department from fire safety point of view and following shortcomings are observed:

1. Travel distance is not meeting the requirement as per clause H 5.4.2 of NBCS 2026 Part F read with clause 4.4 of NBCS 2026 Part F.
2. Details of evacuation, including time calculation as per NBCS 2026 Part F, have not been provided.

In view of above, the building plans are rejected.

Yours faithfully


(A. K. Malik)
Chief Fire Officer,
Delhi Fire Service

24/6/26