

c/68

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2025/ 223

Dated:-09/05/2025

To

The Manager  
M/s J. J. International Guest House,  
265 to 270, Mantola, Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M/s J. J. International Guest House, 265 to 270, Mantola, Pahar Ganj, New Delhi.

Sir,

This has reference to online id no. 2025041206304 dated 12/04/25, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 01/05/25 in the presence of Mr. Mehboob and following shortcomings were observed:-

1. Smoke management system found nonfunctional.
2. PA system found nonfunctional.
3. Pump not in auto mode provision.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

**Copy to :-**

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.