

C-70

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/SH/NDZ/ 2025/333

Dated:-08/08/2025

To,

The Manager
M/s JMD, Hotels Pvt. Ltd,
G-6, Janak Place, District Center,
Janakpuri, Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/s JMD, Hotels Pvt. Ltd, G-6, Janak Place, District Center, Janakpuri, Delhi.

Sir,

This has reference to your online id no. 2025070911159 dated 09/07/25, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on dated 26/07/25 in presence of Mr. Pintu Rao, Manager and observed that shortcomings issued earlier vide letter no. F6/DFS/MS/EH/2025/SZ/198 dated 05/05/25 (copy enclosed), have not been complied so far. Further, clear width of 1.5 meter each of exit doors is also required to be provided without any obstructions.

In view of above, the case is rejected and FSC can't be renewed till the compliance of all the shortcomings issued vide aforesaid letter.

Encl: As above.

Yours faithfully,


6/8/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Officer

Copy to :

1. The Commissioner, MCD, Civic Center, New Delhi.

d/s² C-67

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/EH/2025/SZ/ 198

Dated: 05/05/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st Floor,
Police Station, Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Bamissal The Food Court (A Unit of JMD Hotels Pvt. Ltd.) located at G-6, Janak Palace, District Centre, Janakpuri, New Delhi- 110058.

Sir,

This has reference to online application received through MCD portal vide ID-2025040105155, on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by officer concerned of this department on 01/05/2025 in presence of Sh. Suzan Singh. Following shortcoming were observed at the time of inspection.

1. First aid hose reel found provided but not functional.
2. MOEFA found removed.
3. Internal hydrant found provided but not functional.
4. Pumping system found provided but not functional.
5. Terrace level tank of 10,000 ltrs capacity found provided against the requirement of 20,000 ltrs.
6. Exit signage's found removed.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. The owner/ occupier, M/s Bamisaal The Food Court (A Unit of JMD Hotels Pvt. Ltd.) located at G-6, Janak Palace, District Centre, Janakpuri, Delhi- 110058.
2. MCD Portal ID No. 2025040705858.