

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/2025/SZ/ 48  
To

Dated: 31/01/2025

The Authorized Signatory,  
M/s JMD Kohinoor Galleria,  
Plot No-33, L.S.C., Masjid Moth,  
Greater Kailash, New Delhi-110048.

Sub: Regarding issuance of FSC in r/o M/s JMD Kohinoor Galleria, Plot No-33, L.S.C., Masjid Moth, Greater Kailash, New Delhi-110048.

Sir,

This is in reference with letter received through outdoor diary no 10848 dated 30/12/2024 on the subject cited above. In this connection, it is to inform you that the premise have been inspected by officer concerned of this department on 24/01/2025 in the presence of Mr. Ranjit Singh and to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Smoke management provided in the basement but found not working.
2. MOEFA provided but found not working.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE