

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
Connaught Place: New Delhi-110001

No. F.6/DFS/MS/2025/BP/ 90

Dated : 05/03/2025

To,

The Chief Architect,
Central Public Works Department,
Room No. 217-218, A-Wing, Nirman Bhawan
New Delhi.

Subject: Regarding issue of fire safety guidelines in r/o New Hostel Building for School of Engineering & Atal Bihari Vajpayee School of Management & Entrepreneurship (SOE & ABVSME) at JNU Campus, New Delhi.

Sir,

Please refer your ID No. ADG DELHIREGION 20241213/2381 dated 13.02.2025 on the above cited subject. In this connection, this is to inform you that the matter is examined and following shortcomings are observed:

1. Architectural plans in .dwg format are not submitted.
2. Electrical shaft is not protected through fire check door as per clause 3.4.5.4 of part 4 of NBC 2016.
3. Lift lobbies are not protected against the ingress of smoke, as a store is proposed in lift lobby, should not open in lift lobby.
4. Travel distance at upper floors in hostel block-A is not meeting the requirement as per clause 7.8 of UBBL 2016.

Accordingly the case cannot be examined and therefore rejected.

Yours faithfully

(Atul Garg)
Director
011 23414000

CB