



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

75  
आज़ादी का  
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/BP/2025/493

Dated: 10/10/2025

To,

The Chief Architect, CPWD,  
Room No. 217-218, "A" Wing,  
Nirman Bhawan, New Delhi - 110011.

**Sub: Online building plans in r/o proposed construction of New Hostel Building and MLCP for school of engineering & Atal Bihari Bajpayee School of Management and Entrepreneurship at JNU Campus, New Delhi.**

Sir,

Please refer your online file No. ADG DELHIREGION20241213/2381 dated 29/08/2025 on the subject cited above. In this connection it is to inform you that the online building plans have been examined and observed following shortcomings:

**MLCP Building**

1. 6.0 meter wide fire tender movement road, all around the high-rise MLCP building is not proposed as per clause 8.2 of UBBL - 2016.
2. Alternate staircase is not proposed.
3. Inspection ladder for OHT is not proposed.
4. Fire Check door is not proposed in Electric Room.
5. Fire protection arrangements such as underground fire water tank, pump room etc. are not proposed.

Therefore, proposal is rejected.

Yours faithfully

(M.K. Chatopadhyay)  
Dy. Chief Fire officer  
Delhi Fire Service