



FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/School/2026/NDZ/ 90

Dated: 04/07/2026

FIRE SAFETY CERTIFICATE

Certified that the **St. John's Model School** located at Institutional Area, Pocket-III, Mayur Vihar, Ph.1, Delhi-110091, comprised of Ground plus two upper floors only but School is running ground and first floor only (2nd floor used as a church's store) own occupied by St. John's Model School was issued FSC vide letter No. F6/DFS/MS/School/2023/NDZ/106 dated 15/02/2023. The premises was re-inspected by the officer concerned of this department on 22/06/2026 in the presence Sh. N Mathew, Member and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "**Educational**" (Group B) (Ground plus one upper floor) with effect from 04/07/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 & also conditions printed below.

Issued on.....04/07/2026.....at New Delhi by.

(Dr. S. K. TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE OFFICER

To,

1. The Headmistress, St. John's Model School located at Institutional Area, Pocket-III, Mayur Vihar, Ph.1, Delhi 110091.
2. The Dy. Director of Education, D-Block, Anand Vihar, Delhi 110092
Application No -52026020900924 dated: 13/06/2026

Conditions for the validity of Fire Safety Certificate:-

1. FSC is valid for ground and first floor only
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : St. John's Model School
Institutional Area, Pocket-III, Mayur Vihar, Ph. 1,
Delhi-110091
2. Building is comprised of :Ground plus two upper floors only but
School is running ground and first floor only
(2nd floor used as a church's store, Affidavit No. IN-
DL27915518699140Y, dated :08/06/2026 given by
the Headmistress of the school)
3. Type of Occupancy :Educational
4. Type of Case :Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/Schol/2023/NDZ/106 dt 15/02/2023
6. Fire Safety directive letter No. : Circular 262-362 dated 17/01/2005 issued by DoE
7. Date of Inspection : 24/06/2026
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
9. Name and designation of Officer
from the building side :Sh. N. Mathew, Member
10. Year of Construction :2005
11. Applicant's letter No :52026020900924 dated 13/06/2026

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	DoE Circular 17/01/2005 Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	• Road width	06 m	06 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50m / less than 1.50m an additional 0.75m	1.35 mtr & 1.25 mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 no.	01 no.	MR
	e. Width of Corridor	01 mtr	01 mtr	MR (old case)
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A

N/20

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	2,500 ltr	5,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection system provided in the building were tested, checked and found functional at the time of inspection. The shortcomings were issued as per application no. 52026020900924 dated 24/02/2026 have been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule. The FSC issued vide letter no. F.6/DFS/MS/Schol/2023/NDZ/106 dated 15/02/2023 **renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.**

Deepak
29/06/2026
Signature of the Inspecting Officer
Name :-Deepak Kumar
Designation :-ADO (Shahdara)

DO (ED)

Aditya
02/07/26

CFO (East Zone)

Aditya
31/7/26

Principal Director

CFO to issue

Aditya
3/7