



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/GH/NDZ/2024/ 749

Dated: 31/12/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Ref: elt.mcdonline application no. 2024121818143

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s J.P. Inn Guest House located at 4400, Katra Raiji, Basant Road, Pahar Ganj, New Delhi.

Sir,

With reference to the elt.mcdonline application no. 2024121818143 on the subject cited above, it is informed that the said guest house was inspected by the officer concerned of this department on. 23.12.2024 in the presence of Mr. Muttafiq Raza (Manager) and following shortcoming were observed at the time of inspection.

1. Hose reel found non functional.
2. CO detector found non functional.
3. Fire pump having capacity of 220 LPM and head 30 meters has not been provided.
4. Overhead tank capacity of 5,000 litres has not been provided.
5. Standby Power Supply has not been provided.
6. Auto start mechanism of fire pump was found removed.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit

Yours faithfully,

(Atul Garg)

Director
Delhi Fire Service

27/12