

4-
C/156

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/Hospital/2025/SZ/ 307

Dated: 23/06/2025

To

Sh. Satesh Kumar,
ASO (Fire Safety),
Administrative Block,
AIIMS, New Delhi-110029

Sub: Renewal of Fire Safety Certificate in r/o JPN Apex Trauma Centre, (AIIMS), Raj Nagar, New Delhi-110029

Sir,

This has reference to the email received from Id: satesh@aiims.gov.in dated 22/05/2025, on the subject cited above. In this connection, the officer concerned of this department visited the premise on dated 11/06/2025 in the presence of Sh. B.S. Yadav (Dy. CSO) to verify the compliance of shortcomings issued by this department vide letter No. F.6/DFS/MS/Hospital/SZ/2024/85 dated 29/02/2024 and the status of shortcoming observed is as below.

S. No.	Shortcomings issued	Present Status
1.	Half of the smoke ventilation system in basement found non-functional.	Not Complied
2.	Some of the sprinklers are above ventilation duct in basement.	Not Complied
3.	Hose Reels provided but non-functional in Blk A.	Complied
4.	The internal hydrants non-functional and rusted/corroded.	Not Complied
5.	Some of the yard hydrant hose boxes without hoses and branch	Complied
6.	Fire pumps still not on auto mode.	Complied

Additional observation :-

1. Lifts provided found under repair/replacement.

In view of the above, the renewal of fire safety certificate cannot be considered at this stage. You are requested to complete the repair/renovation work under intimation to this department for further action in the matter.

Yours faithfully/

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

01/08/25