



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-6

No: F.6/DFS/MS/School/2025/WZ/ 688

Dated: 25/08/2025

To,

The Principal,  
J.S. Memorial Public School,  
Holambi Kalan, Delhi-110082.

Sub: Regarding issuance of Fire Safety Certificate in r/o J.S. Memorial Public School located at Holambi Kalan, Delhi- 110082.

Sir,

This has reference to your email id dated 30.06.2025 on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department on 26.07.2025 to ascertain the availability and operability of the fire prevention and fire safety measure, Sh. Gaurav Tyagi was present at the time of inspection. During the course of visit it was observed that building is comprised of Ground and First Floor.

Your request for issuance of FSC is rejected due to the following shortcoming:-

1. 4.5 m wide dirt/ kaccha road found provided against the required RCC road of 6 m width.
2. There is only 01 staircase of 1 m provided against the requirement of 02 staircases of 1.5 m width each.
3. Class room door width found 0.95 m against the required width of 1.20 m.
4. Fire extinguishers not provided.
5. First aid hose reel not provided.
6. Terrace level pump of 450 lpm discharge capacity not provided.
7. Overhead tank of 10,000 ltrs water storage capacity not provided.
8. Exit signages not provided.
9. Building plan on a scale of 1:100 duly signed by registered architect and owner not provided.

You are advised to rectify the above-mentioned **shortcomings** under intimation to this department.

Yours Faithfully

25/08/2025  
(Virendra Singh)  
Chief Fire Officer

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.