



215

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 806

Dated: 12/11/2025

To

The Manager
J.S.S Khalsa School,
T-1 BudhVihar, Phase-1
Delhi-110085.

Sub: - Regarding renewal of fire safety certificate in r/o J.S.S. Khalsa School located at T-1, Budh Vihar, Phase-I, Delhi-110086.

Sir,

Please refer to your letter no- J.SSKS/BV/43/2025 dated 17/09/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 01/11/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 02 blocks, one block comprised, of ground & first floor & second block, comprised of ground floor only. At the time of inspection Sh. Roop Singh (Manager) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire extinguishers are provided but not functional.
2. Hose reel hose is provided but not functional and in damaged condition.
3. Terrace level fire pump capacity of 450lpm provided but not functional.
4. Terrace level fire water tank capacity of 5,000 LTR is provided against the requirement of 10,000 LTR.
5. Exit & floors signage's found removed at strategic location in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully


10/11/25
(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi - 110085.