

C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2025/ 399

Dated: - 10/10/2025

To,

The Owner/Occupier,
Ms. Jubilant Food Works Limited Dominos Pizza,
GF, Shop No. 3, Near Gate No. 1,
Shahdara Metro Station, New Delhi- 110032.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o M/s. Jubilant Food Works Limited Dominos Pizza, GF, Shop No. 3, Near Gate No. 1, Shahdara Metro Station, New Delhi- 110032.


Sir,

Please refer to online application ID 2025091113364 dated 12.09.2025, on the subject cited above. In this connection it is to inform you that the above said eating house building have been inspected by the officer concerned of this department, in presence of Manager, on dated 24.09.2025, to check the status of the shortcomings already pointed out by this department vide letter No. F.6/DFS/MS/EH/2025/SZ/152 dated 07.04.2025 (copy enclosed). During the course of inspection, it was observed that the shortcomings are not fully complied. This department already issued letter in this matter vide letter No. F.6/DFS/MS/EH/2025/NDZ/290 dated 24.06.2025.

In view of the above, issuance of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running eating house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Encl: - as above

Yours faithfully


(Dr.S.K. Tomer)
Dy. Chief Fire Officer
New Delhi Zone
9/10/25

C-22C-8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/EH/2025/SZ/ 152

Dated: 07/04/2025

To,

The Joint C.P. (LIC.),
1st floor, Police Station,
Defense Colony, New Delhi.

Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o M/s Jubilant FoodWorks Limited Domino's Pizza located at Shop No. 3, UGF, Shahdara Metro Station, New Delhi-32.

Sir,

Please refer to online application ID 2025031103310 dated 11.03.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the aforesaid eating house building on dated 28.03.2025 in the presence of Sh. Narayan Pandey, to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the above said eating house/restaurant running at upper ground floor only in a building comprised of lower ground floor and upper ground floor, and have following shortcomings: -

1. Terrace fire pump capacity of 450 LPM provided but found common with Burger King restaurant. A separate terrace fire pump capacity of 450 LPM should be provided.
2. Overhead water storage tank capacity of 20,000 ltrs. provided but found common with Burger King restaurant. A separate water storage tank capacity of 20,000 ltrs should be provided.
3. Exit Signages found not provided.

Keeping in view of above, issuance of fire safety certificate can-not be considered at this stage. Management of the restaurant may be requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department and running restaurant/eating house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Atul Garg)
Director
Delhi Fire Service

Copy for information: -

The Owner/Occupier, M/s Jubilant FoodWorks Limited Domino's Pizza located at Shop No. 3, UGF, Shahdara Metro Station, New Delhi- 110032.