



e 6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F.6/DFS/MS/EH/SZ/2026/ 424

FIRE SAFETY CERTIFICATE

Dated: 30/04/2026

Certified that the Eating House in the name of M/s. Jubilant Food Works Limited Dominos Pizza, located at, Ground Floor, Okhla Vihar Metro Station, Line 8, New Delhi-110025, in the building comprised of 04 Level (Ground + first + Concourse & Platforms). Owned/Occupied by M/s. Jubilant Food Works Limited Dominos Pizza, The premises was inspected by the officer concerned of this department on 22/04/2026 in the presence Sh. Puneet Jain and found that the said premise have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy Class "Assembly" (Group-D) (Restaurant at Ground Floor only) and validity up to 31/03/2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 30/04/2026 at New Delhi by

(A.K. Malik)

Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002. to ensure the occupancy as detailed above & deviation if any
2. Owner/ Occupier, M/s. Jubilant Food Works Limited Dominos Pizza, located at, Ground Floor, Okhla Vihar Metro Station, Line 8, New Delhi-110025. (Online Portal ID No. -2026040204159 dated-02/04/2026)
3. Sh. Vivek Srivastava (JGM/E&M), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building	M/s. Jubilant Food Works Limited Dominos Pizza, located at, Ground Floor, Okhla Vihar Metro Station, Line 8, New Delhi-110025.			
2. Type of Occupancy	Group-D Assembly Building, Eating house at Ground Floor only. In Okhla Vihar Metro Station Line-8			
3. Type of Case	New Case			
4. Details of Previous NOC	Nil			
5. Fire Safety directives letter No	F.6/DFS/MS/Assembly/2024/SZ/388 dated-24/06/2024 (Metro Station NOC)			
6. Date of inspection	22/04/2026			
7. Name of Inspecting Officer	Sh. Sarabjeet Singh ADO (BCP)			
8. Name and designation of officers From the building side	Sh. Puneet Jain			
9. Year of Construction	2000 (As per online application)			
10. Applicant's letter No.	Online-ID No – 2026040204159 dated-02/04/2026			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	F.6/DFS/MS/Assembly/2024/SZ/388 dated-24/06/2024 (Metro Station NOC)		
	• Road width	30m	Provided*	MR
	• Gate width	06m	Provided*	MR
	• Width of internal road	06m	Provided*	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Provided & Maintained by Metro Station		
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	Provided & Maintained by Metro Station		
	• Upper Floor	NA	NA	NA
	• Basements	NA	As above	NA
	c. Protection of exits	Provided & Maintained by Metro Station		
	• Fire check door	NA	NA	NA
	• Pressurization	NA	As above	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2x1.5m	Provided	MR ✓
3.	Compartmentation	Provided & Maintained by Metro Station		
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management System	Provided & Maintained by Metro Station		
	a) Basements	NA	NA	NA
	b) Upper floors	Required	Provided*	MR
5.	Fire Extinguishers			
	a) Total numbers	06 Nos.	06 Nos.	MR
	b) Types	ABC/CO ₂	ABC-07 & CO ₂ -03	MR
	c) IS marking	ISI marked	Provided	MR

6.	First-Aid Hose Reels		Provided & Maintained by Metro Station	
	a) Total numbers on each floor	01 No near restt.	Provided*	MR
	b) Length of hose reel hose	30mm	Provided*	MR
	c) Nozzle diameter	5m	Provided*	MR
7.	Automatic fire detection and alarming system		Provided & Maintained by Metro Station	
	a) Type of detectors	NA	As above	NA
	b) Location of Main Panel	NA	As above	NA
	c) Location of Repeater Panel	NA	As above	NA
	d) Alternate source of power	NA	As above	NA
	e) Hooters' Location	NA	As above	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System		Provided & Maintained by Metro Station	
	a) Basement	NA	NA	NA
	b) Ground & Upper Floors	NA	As above	NA
	c) Sprinkler above false ceiling	NA	Provided*	NA
11.	Internal Hydrants		Provided & Maintained by Metro Station	
	a) Size of riser/down-comer	100mm.	Provided*	MR
	b) Number of hydrants per floor	01 Nos.	Provided*	MR
	c) Hose Box	01 Nos.	Provided*	MR
12.	Yard Hydrants			
	a) Total number of hydrants	NA	As above	NA
	b) Hose Box	NA	As above	NA
13.	Pumping Arrangements			
	• Ground Level	Provided & Maintained by Metro Station		
	➤ Discharge of main Pump	NA	1800LPM	NA
	➤ Head of Main pump	NA	70m	NA
	➤ Number of main pumps	NA	01nos.	NA
	➤ Jockey Pump out put	NA	180LPM	NA
	➤ Jockey pump head	NA	70m	NA
	➤ Standby Pump out put	NA	1800LPM (electric)	NA
	➤ Standby Pump Head	NA	70m	NA
	➤ Auto Starting/Manual Stopping	NA	Provided*	NA
	➤ Pump House Access	NA	Provided*	NA
	Terrace level			
	➤ Discharge of pump	450LPM	As above	MR ✓
	➤ Head of the pump	40m	As above	MR
	➤ Power Supply	Required	Provided*	MR
	➤ Auto Starting of pump	Required	Provided*	MR
14.	Captive Water Storage for firefighting		Provided & Maintained by Metro Station	
	• Underground tank capacity	NA	50,000ltrs	NA
	➤ Draw-off connection	NA	As above	NA
	➤ Fire service inlet	NA	As above	NA
	➤ Access to tank	NA	As above	NA
	• Overhead Tank capacity	20,000 ltrs	As above	MR /
15.	Exit Signage.	Required	Provided	MR

~13

16.	Provision of Lifts	Provided & Maintained by Metro Station		
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	Fire Control Room	Provided & Maintained by Metro Station		
	a) Detector System Panel	NA	As above	NA
	b) Flow Switch Panel	NA	As above	NA
	c) PA System Panel	NA	As above	NA
	d) Battery backup	NA	As above	NA
	e) Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Note-* Fire safety arrangements provided & maintained by Okhla Vihar Metro Station of Line-8.

The fire protection systems provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention & fire safety requirement under the rules and it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010.

Accordingly, DFA is put up for approval and signatures please.

Last Date of Disposal-1/05/2026


 Signature of the Inspecting Officer
 Name - Sarabjeet Singh
 Designation - ADO(BCP)

DO (SD)


 24/4/26

Ravinder Singh

CFD (S)


 24/4/26
A.K. MALIK

Principal Engineer

CFD to Secy.

DO (SD)


 28/4/26
A.K. MALIK

CFD (S)


 27/04/26