

C-48 75

आज़ादी का
अमृत महोत्स

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/NDZ/2025/196

Dated: 15/05/2025

FIRE SAFETY CERTIFICATE

Certified that the Jubilant Food works Ltd., (Domino's Pizza) located at Shop No. G-2, Ground Floor & Mezzanine Floor, Dilshad Garden Metro Station, Delhi-110095, owned / occupied by Jubilant Food works Ltd., (Domino's Pizza), building comprised of Ground & Two Upper Floors only but **restaurant running on Ground & Mezzanine Floor** only was earlier issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2022/EH/NDZ/141 Dated 24/05/2022. The premises was re-inspected by the officer concerned of this department on 07/05/2025 in the presence of Sh. Sachin (Manager) and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Assembly" (Group-D) for Ground & Mezzanine floor only with effect from 15/05/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on15/05/2025..... at New Delhi.

(ATUL GARG)
DIRECTOR

Copy to :-

1. Joint Commissioner of Police (Lic.) P. S.: Defence Colony, New Delhi-110024 w.r.t. MHA portal ID-2025042407068 dated 24/04/2025.
2. Sh. Naveen Gupta, M/s Jubilant Food works Ltd., (Domino's Pizza), Shop No. G-2, Ground Floor & Mezzanine Floor, Dilshad Garden Metro Station, Delhi-110095.

Conditions for the validity of Fire Safety Certificate:-

1. This Fire Safety Certificate is valid for Ground & Mezzanine floor only.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. The trained fire- fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. Basement shall be used strictly as per Building By-Law.
7. This certificate cannot be treated in any case for regularizations of unauthorized construction.
8. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
9. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Jubilant Food works Ltd., (Domino's Pizza), Shop No. G2, Ground Floor & Mezzanine Floor, Dilshad Garden Metro Station, Delhi-110095.
2. Building is comprised of : Ground & Two Upper Floors only
(Restaurant on Ground & Mezzanine Floor)
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2022/EH/NDZ/141 Dated 24/05/2022
6. Fire Safety directives Letter No. : NBC (Part-IV)
7. Date of inspection : 07/05/2025
8. Name of the Inspecting Officer : Suman Kumar (A.D.O.)
9. Name and designation of Officer from the building side : Mr. Sachin (Manager)
10. Year of Construction : 2008
11. Applicant's MHA Portal No. : 2025042407068 dated 24/04/2025

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC (Part-IV) Requirements | Provided at site | Remarks MR/NM R |
|------|---|-----------------------------------|------------------|-----------------|
| 1. | Access of building | | | |
| | • Road width | 12 mtr | 28 mtr | MR |
| | • Gate width | 4.5 mtr | 6 mtr | MR |
| | • Width of internal road | 6 mtr | 6 mtr | MR |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 2 | 2 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1.50 mtr | 1.50 mtr each | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | 2 mtr & 1.50 mtr | Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | Required | Provided | MR |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | 12 a/c per hour | Provided | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 3 | 9 | MR |
| | • Types | ISI marked ABC/CO ₂ | Provided | MR |
| | • IS marking | Required | Provided | MR |

| | | | | |
|-----|--|---------------------------|--------------|----|
| 6. | First - Aid Hose Reels | | | |
| | • Total numbers on each floor | 1 | 1 | MR |
| | • Length of hose reel hose | 30 mtr. | 30 mtr. | MR |
| | • Nozzle diameter | 5mm. | 5mm. | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | NA | Smoke & Heat | NA |
| | • Location of Main Panel | NA | Provided | NA |
| | • Location of Repeater Panel | NA | Provided | NA |
| | • Alternate source of power | Required | Provided | MR |
| | • Hooters' Location | Near Gate | Provided | MR |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | Provided | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down- comer | 100 mm | Provided | MR |
| | • Number of hydrants per floor | 1 | Provided | MR |
| | • Hose Box | 1 | Provided | MR |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | Common with Metro Station | | |
| | • Discharge of main pump | 1800 LPM | Provided | MR |
| | ➤ Head of main pump | 40 M | Provided | MR |
| | ➤ Number of main pumps | 2 | Provided | MR |
| | ➤ Jockey pump out put | 180 LPM | Provided | MR |
| | ➤ Jockey pump head | 40 M | Provided | MR |
| | ➤ Standby Pump out put | 1800 LPM | Provided | MR |
| | ➤ Standby Pump Head | 40 M | Provided | MR |
| | ➤ Auto Staring/Manual stopping | Required | Provided | MR |
| | ➤ Pump House Access | Required | Provided | MR |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power supply | NA | NA | NA |
| | ➤ Auto starting of pump | NA | NA | NA |
| 14. | Captive water Storage for fire fighting | | | |
| | • Underground tank capacity | 50, 000 ltr | 2,00,000 ltr | MR |
| | ➤ Draw of connection | Required | Provided | MR |
| | ➤ Fire service inlet | Required | Provided | MR |
| | ➤ Access to tank | Required | Provided | MR |
| | • Overhead Tank capacity | NA | NA | NA |

N-9

| | | | | |
|-----|--|----------|----------|----|
| 15 | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area | | | |
| | ➤ Total area | NR | NR | NR |
| | ➤ Location | NR | NR | NR |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NR | NR | NR |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2022/EH/NDZ/141 Dated 24/05/2022 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

08/05/2025

Signature of the Inspecting Officer
Name : Suman Kumar
Designation : A.D.O.

DO (E)

Sy C.F.O. (NDZ)

C.F.O.

13/5/2025

Director

17/6/2

AD / Suman