



c/34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/EH/2025/EZ/ 269

Dated: 16/06/2025

To,

The Joint Commissioner of Police (Lic),
1st Floor, Defence Colony Police Station,
New Delhi- 110049.

Sub:- Regarding renewal of Fire Safety Certificate in r/o M/s Jubliant Food Works Ltd. (Domino's Pizza) at Ground Floor, Shop No. G-40, Vikas Cine Mall, Shahdara, Delhi- 110032.

Sir,

This has reference to online application received through MCD portal vide ID- 2025052709153 dated 23/05/2025 on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by officer concerned of this department on 06/06/2025 and observed that of the shortcomings issued by this department vide letter No.F6/DFS/MS/EH/2025/SZ/220 dated 19/05/2025 are still not complied (copy enclosed).

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully


(Atul Garg)
Director
Delhi Fire Service


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2025/SZ/220
To

Dated: 19/05/2025

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Jubilant Food Works Ltd (Domino's Pizza) at Ground Floor, Shop No G-40, Vikas Cine Mall, Shahdara Delhi 110032.

Sir,

This has reference to your **MCD Portal ID 2025042407065** dated **24/04/2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 09.03.2025 in the presence of Ms. Nisha (Manager) to verify the fire safety measures installed in the building and observed that the building is comprised of 02 Basement, Ground plus 04 upper floors and restaurant is running at ground floor only. During inspection, following points were observed:

- 1 Terrace level fire fighting pumps capacity 450 LPM found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE