



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/GH/2025/SZ/ **399**

Dated: **22/09** /2025

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre,
New Delhi-110002

Sub: Renewal of Fire Safety Certificate in r/o M/s K 87 Orchid Garden situated at 51/1, Opp. Khalsa College, D.B. Gupta Road, Delhi-110005

Sir,

This has reference to the online portal application No. 2025082812981 dated 28/08/2025. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on 10/09/2025 in presence of Mr. Sawant Gupta (Manager) to verify the compliance of shortcomings issued vide this office letter No. F.6/DFS/MS/WZ/GH/2025/365 dated 27/08/2025 and observed that the shortcomings are not yet complied.

In view of above, application for renewal of fire safety certificate cannot be considered & rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(Virendra Singh)
Chief Fire Service
Delhi Fire Service


Copy to: -

1. Nodal Officer/DFS with the request to upload on online MCD Portal.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001



No. F.6/DFS/MS/WZ/GH/2025/ 365

Dated: 27/08/2025

To,

Mr. Amit Jain,
House No.144, Old Gupta Colony,
Dr. Mukerjee Nagar,
New Delhi-110009.

Sub: Renewal of FSC in r/o M/s K 87 Orchid Garden, located at 51/1, opp. Khalsa College, D.B.Gupta Road, Delhi-110005.

Sir,

This is refer to online application no. 2025072811965 dated 04.08.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **11.08.2025**, in presence of **Mr. Sawan Kumar (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of **FSC is rejected** under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fir Check Door is not provided at some places in staircase & fire glass found replaced with ordinary glass in some FCD
2. Hose reel provided but not functional.
3. Automatic fire detection system provided but not functional.
4. MOEFA is provided but not functional.
5. Terrace Fire pump with capacity of 450 LPM provided but not functional.
6. Standby power supply not provided.
7. A temporary room found on terrace of 3rd floor used by staff of guest house.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


26/8/2025

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service



Copy To:-

1. MCD Portal Id- 2025072811965 dated 04.08.2025.