



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/WZ/GH/ 311

Dated: 06/05/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M/s K. G. Palace located at 1656-57, Plot No.4, Kh No.561-4, Main Bazar, Pahar Ganj, Delhi-110055, comprised of ground + 04 upper floors but guest house running at 1<sup>st</sup> to 3<sup>rd</sup> upper floors only, Gr. floor-Reception + office, 1<sup>st</sup> to 3<sup>rd</sup> floor-(06 guest rooms at each floor), total-18 guests rooms only has already been issued FSC by this department vide letter No. F.6/DFS/MS/GH/NDZ/2022/31 dated 17.01.2022. The premises was re-inspected by the officer concerned of this department on 28.04.2025 in the presence of Mr. Vishal Rajput and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Residential, Sub Division-A-1, for 1<sup>st</sup> to 3<sup>rd</sup> floor only, total-18 guest rooms up to 3<sup>rd</sup> floor only with effect from 06/05/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/05/2025 at New Delhi by

(Atul Garg)  
DIRECTOR

Ph; 011-23414000

Copy to :-

1. MCD Portal ID-2025040906003 dated 11.04.2025.
2. The Commissioner MCD, Civic Centre, New Delhi, with a request to ensure the occupancy as detailed.
3. The Joint Commissioner of Police (Lic.) 1<sup>st</sup> floor, Licensing unit, Police Station, Defence Colony, New Delhi-.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)



INSPECTION REPORT				
1. Name & address of the building	M/s K. G. Palace located at 1656-57, Plot No.4, Kh No.561-4, Main Bazar, Pahar Ganj, Delhi-110055			
2. Type of Occupancy	Residential, Sub-Division-A-1			
3. Comprised of building	Ground + 04 upper floors			
4. Type of Case	Renewal (guest house running at 1 <sup>st</sup> to 3 <sup>rd</sup> floors, 06 guest rooms at each floor, Total-18 guest rooms only) Gr. floor-Reception + office, 1 <sup>st</sup> to 3 <sup>rd</sup> floor-06 guest rooms at each floor total-18 guests rooms and terrace floor-staff rooms + staff kitchen given an affidavit dated 05.12.2019 regarding not to use any floor above 3 <sup>rd</sup> floor.			
5. Details of Previous NOC	F.6/DFS/MS/GH/NDZ/2022/31 dated 17.01.2022.			
6. Fire Safety directives letter No	-NA-			
7. Date of inspection	28.04.2025			
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
9. Name and designation of officers From the building side	Mr. Vishal Rajput			
10. Year of Construction	2008 on MCD Portal			
11. Applicant's letter No.	Online application No. 2025040906003 dated 11.04.2025			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement/Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	-NA-	More then 06 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	01nos.	01nos.	MR
	• Basements	-NA-	-NA-	-NA-
	<b>b. Width of staircases</b>			
	• Upper Floor	1.25m	1.25m	MR
	• Basements	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	-NA-	-NA-	-NA-
	<b>e. Width of Corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door Size</b>	1.0m	1.0m	MR
3.	<b>Compartmentation</b>			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural/Exhaust fan	MR
5.	<b>Fire Extinguishers</b>			
	a) Total numbers	10nos.	Provided	MR



	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	a) Total numbers on each floor	01nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	a) Type of detectors	Required	Provided	MR
	b) Location of Main Panel	Gr. floor	Provided	MR
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	Each floor	Provided	MR
<b>8.</b>	<b>MOEFA</b>	-NA-	-NA-	-NA-
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
<b>11.</b>	<b>Internal Hydrants</b>			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
<b>12.</b>	<b>Yard Hydrants</b>			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
<b>13.</b>	<b>Pumping Arrangements</b>			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	180lpm	180lpm	MR
	➤ Head of the pump	30m	30m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	2500ltr	2500ltr	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>	<b>One lift Gr. to 3<sup>rd</sup> floor</b>		

N/24

a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
c) Communication In lift Car	Required	Provided	MR
d) Fireman's Grounding Switch	Required	Provided	MR
e) Lift Signage	Required	Provided	MR
17. Standby power supply	Required	Provided	MR
18. Refuge Area.			
a) Total Area	-NA-	-NA-	-NA-
b) Location	-NA-	-NA-	-NA-
19. Fire Control Room			
a) Detector System Panel	-NA-	-NA-	-NA-
b) Flow Switch Panel	-NA-	-NA-	-NA-
c) PA System Panel	-NA-	-NA-	-NA-
d) Battery backup	-NA-	-NA-	-NA-
e) Building Floor Plans	-NA-	-NA-	-NA-
20. Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the <sup>FSC</sup> (NOC) issued vide letter no. F.6/DFS/MS/GH/NDZ/2022/31 dated 17.01.2022 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

DO (C)

30/4/25

Dy. C.F.O. (NDZ)

20/4/25

C.F.O.

2/5/2025

Director

2/5/24

Director 4/5/24

ADP

FT letter to put up for renewal and sign please.

U/Handed 07/5/25

3/5/25