



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आप्लादीय
अमृत महोत्सव

No. F6 /DFS/MS/Industrial/SZ/2025/ 152

Dated: 07/04/2025

To,

The Owner/Occupier/Manager,
M/s Kabir Agencies LLP,
Plot no. E-20, B-1 (Extension),
Mohan Co-operative Industrial Estate, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o **M/s Kabir Agencies LLP** located at
Plot no. E-20, B-1 (Extension), Mohan Co-operative Industrial Estate, New Delhi.

Sir,

With reference to the letter bearing outdoor diary no. 14601 dated 18.03.2025 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 20.03.2025 in the presence of Mr. Mr. Shambhu (Caretaker) and following shortcomings were observed:

1. Two no. of Staircases having width 1.50 meters each has not been provided.
2. Fire Check Door (FCD's) not bears standardization meetings.
3. Diesel pump not provided & others fire pumps not in auto mode.
4. Underground fire tank 1,00,000 liters & Terrace fire tank 50,000 liters has not been provided.
5. Lift lobby found removed.
6. Caretaker room on terrace (semi pucca) must be removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.