

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/2025/ 239

Dated 26/05/2025

To,

Mr. Sadhu Ram Goyal(G.M. Finance),
Kailash Building, 26, Kasturba Gandhi Marg,
New Delhi-110001.

**Sub:-Regarding renewal of FSC in r/o Kailash Building, 26, Kasturba Gandhi Marg,
New Delhi-110001.**

Sir,

This has reference to your letter no. nil dated 25.04.2025, on the subject cited above. In this regard the site was inspected by the officer concerned of this department on 15/05/2025 in the presence of Sh. Omprakash & Sh. Pitambar and the following shortcomings were observed:-

1. Fire check doors in basement found removed.
2. Door closers from fire check door found removed at some floor.
3. Smoke Management system in basement found nonfunctional.
4. Fire service inlet found non functional
5. Draw off connection found not approachable for fire tender.

In view of above shortcomings, the application for renewal of FSC is rejected. The occupancy in the building in absence of requisite fire safety arrangements shall be at risk and liability of owner /occupier. Further, statutory authority / building sanctioning authority may take necessary action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. Sh. S.K. Goyal (G.M. Finance), Kailash Building, 26, Kasturba Gandhi Marg, New Delhi-110001.