



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/WZ/EH/2026/ 562

Dated: 9/06/2026

To,

The Commissioner,  
MCD, Civic Center, Minto Road,  
New Delhi-110002.

Sub: Renewal of FSC in r/o M/s Kaleva Foods, located at Shop No.GD-28, GF, Pitampura, Delhi-110034.

Sir,

This is refer to online application no. 2026051206733 dated 12.05.2026, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 01.06.2026, in presence of Mr. Aakash to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason

1. First Aid hose reel provided but not functional.
2. Manually operated electric fire alarm system found removed.
3. Internal hydrants provided but not functional.
4. Terrace Fire pump with capacity of 450 LPM provided but not functional.
5. 10,000 Itrs Over Head water captive tank provided against the required capacity of 20,000 Itrs

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully,



(S. K. Dua)

Chief Fire Officer  
Delhi Fire Service



Copy to :

1. MCD Portal Id-2026051206733 dated 12.05.2026.