

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F.6/DFS/MS/EH/2025/SZ/ 241

Dated: 19/06/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s **Kali Ghata Misthan Bhandar Private Limited**, running at ground and first floor only in a building comprised of basement (other property), ground plus three upper floors (second & third floor is vacant and not in use), located at Property No. E-1079 & 1080, Main CCRT Road, Ramphal Chowk, Sector- 7, Dwarka, New Delhi- 110075, owned/occupied by M/s Kali Ghata Misthan Bhandar Private Limited, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on dated 06.06.2025 in the presence of Sh. Vikas (Manager), and found that the building/premises is fit for occupancy class Group "D" Assembly Building" (for ground & first floor only) w.e.f. 19/06/2025 for a period of **three** years, accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 19/06/2025 at New Delhi.

(Atul Garg)
Director

Delhi Fire Service

Online application Id 2025051908683 dated 20.05.2025

Copy to: - The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.

: -for information regarding use of basement (other

property)

Conditions for validity of Fire Safety Certificate: -

1. **This FSC is valid only for ground & first floor.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. Basement strictly shall be used as per BBL/UBBL.
8. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Kali Ghata Misthan Bhandar Private Limited at E-1079 & 1080, GF & FF, Main CCRT Road, Ramphal Chowk, Sec. 7, Dwarka, New Delhi- 110075.
2. Building is comprised of : B, G+3 upper floors, Basement (other property), Ground & 1st floor (Kali Ghata), 2nd & 3rd floor (Vacant)
3. Type of Occupancy : Group D (Assembly) Misthan Bhandar running at ground & 1st floor only
4. Type of Case : New Case
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 06.06.2025
8. Name of Inspecting Officers : A.D.O. R.K. Yadav (JKP)
9. Name and designation of officers :
From the building side : Mr. Vikas (Manager)
10. Year of Construction : 2015
11. Applicant's letter No. : MHA Portal ID 2025051908683 dated 20.05.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements Under 35 (6)	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 mtrs. N/A N/A	Provided N/A N/A	M/R N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no's N/A	02 no's N/A	MR Other property
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m each N/A	1.50 m & 1.35 to 1.50 m N/A	MR Other property
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01 No's N/A	Provided N/A	MR N/A
	e. Width of Corridor	02 No's	1.50 m each	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A 12 ACPH	N/A Exhaust Fan Provided	Other property MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers in restaurant Types IS marking 	08 no.'s ABC/CO ₂ ISI marked	Provided ABC- 04 & Co2- 04 Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers at each floor Length of hose reel hose Nozzle diameter 	1 Nos. 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R

7.	Automatic fire detection and alarming system in restaurant			
	<ul style="list-style-type: none"> Type of detectors Smoke/Heat Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Heat & smoke Required N/A Required N/A	Provided Provided N/A Provided N/A	M/R M/R N/A MR N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	N/A Required N/A	N/A Provided N/A	Other property MR N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box 	100 mm 01 no's 01 no's	Provided Provided Provided	M/R M/R M/R
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Water curtain Pump Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A 450 LPM 40 m Required Required	N/A 900 LPM 40 m Provided Provided	N/A M/R M/R M/R M/R
14.	Captive Water Storage for fire-fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 20,000 ltrs	N/A N/A N/A N/A 20,000 ltrs	N/A N/A N/A N/A M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A

197


17.	Standby power supply			
8.	Refuge Area.	Required	Provided (DG Set)	M/R
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - As per affidavit submitted by the eating house/restaurant management (placed at C-19) that the M/s. Kali Ghata Mithan Bhandar running at ground and first floor only in a building comprised of basement, ground plus three upper floors, Basement of the building is other's property, 2nd and 3rd floor of the building is vacant and not in use. The total covered area of eating house/restaurant as per MHA CAF portal is 192 Sq mtr., so sitting capacity comes $(192/1.8 = 107)$ 107 persons


Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule 2010.

Accordingly, DFA letter is put up for approval & signature please.


 Signature of the Inspecting Officer
 Name- R.K. Yadav
 Designation: - ADO (JKP)

DO (SW)


13/6/25


16/6/2025

Director

As approved, F.T. letter is put up for signature pl.

Director 

UPDated
20/6/25


18/6/25