

015

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001

No.F.6/DFS/MS/School/2025/SZ/ 228

Dated: 10/03/2025

FIRE SAFETY CERTIFICATE

Certified that the **Kamal Kindergarten** at K-1 Extn., L-Block, Mohan Garden, New Delhi-110059 comprised of ground floor plus three upper floors and a small basement (closed), owned/occupied by the Great Vaibhav Educational & Welfare Society was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2022/SZ/449 dated 25.04.2022. The School building was re-inspected by the officer concerned of this department on 04.03.2025 in the presence of Sh. Ajeet Popli and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (**Except Basement**) is fit for occupancy class "**Educational Building**" w.e.f. 10/03/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 10/03/2025 at New Delhi by.


(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi: - for information regarding use of basement.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
3. The Principal, Sushil International School at Hans Nagar, Pandwala Village, New Delhi- 43.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws. Presently basement is sealed by owner.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/12

INSPECTION REPORT

1. Name & address of the building : Kamal Kindergarten, K-1 Extn., L-Block, Mohan Garden, New Delhi-110059
2. Building comprised of : Ground plus three upper floors and a small basement (closed)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/449 dated 25.04.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 04.03.2024
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Dr. Ved Tandon
10. Year of Construction : 2009
11. Applicant's letter No. : KKG/2025/243 dated 14.02.2025

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC/BBL Requirements | Provided at site | Remarks MR/NMR |
|--------|---|---|------------------------------------|---------------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | Accessible (06 m) 4.5 m N/A | Provided Provided N/A | M/R M/R N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floors Basements | 02 No.'s N/A | 02 No's N/A | M/R N/A |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor Basements | 1.50 & 1.25 m N/A | 1.50 & 1.27 m N/A | M/R N/A |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door Pressurization | N/A N/A | N/A N/A | N/A N/A |
| | d. No. of continuous staircases to terrace | Required | Provided | M/R |
| | e. Width of Corridor | 1.50 m | 1.65 m | M/R |
| | f. Class room Door Size | 1.0 m | 1.0 m | M/R |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | N/A Required | N/A Natural ventilation | N/A M/R |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 09 no's ABC/CO ₂ type ISI marked | Provided Provided ISI marked | M/R M/R M/R |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | One 30 m 5 mm | Provided Provided Provided | M/R M/R M/R |

| | | | | |
|-----|--|-------------|----------|-----|
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | N/A | N/A | N/A |
| | | 450 LPM | Provided | M/R |
| | | 30 m | Provided | M/R |
| | | Required | Provided | M/R |
| | | Required | Provided | M/R |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | 10,000 ltrs | Provided | M/R |
| 15. | Exit Signage. | Required | Provided | M/R |
| 16. | Provision of Lifts. (No Lift) | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |

N/14

| | | | | |
|-----|---|-----|-----|-----|
| | Standby power supply | N/A | N/A | N/A |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2022/SZ/449 dated 25.04.2022, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

D.O. (South West)

[Signature]
5/3/25

CFO
[Signature]
6/3/2025

Director

[Signature]
4/3/25
AD/JKP

FT letter is put up for sign please

[Signature]
DIRECTOR

[Signature]
07/3/2025