

0/12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No.F.6/DFS/MS/School/2025/SZ/ 231

Dated: 10/03/2025

FIRE SAFETY CERTIFICATE

Certified that the **Kamal Model Sr. Sec. School** at K-1 Extn., Mohan Garden, New Delhi-110059, comprised of two separate basement (storage), ground floor plus three upper floors, owned/occupied by Kamal Model Sr. Sec. School was issued Fire Safety Certificate by this department vide letter F6/DFS/MS/School/2022/SZ/448 dated 25.04.2022. The school building was re-inspected by the officer concerned of this department on dated 04.03.2025 in the presence of Dr. Ved Tandon, and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational**" w.e.f. 10/03/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.
Issued on 10/03/2025 at New Delhi by.

(Amit Garg)
Director
Delhi Fire Service

Copy to: -

1. The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi: - for information regarding use of basement.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
3. The Principal, Kamal Model Sr. Sec. School at K-1 Extn., Mohan Garden, New Delhi-110059.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws. Presently basement used for storage only.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/23

INSPECTION REPORT

1. Name & address of the building : Kamal Model Sr. Sec. School at K-1 Extn., Mohan Garden, New Delhi-110059.
2. Building comprised of : 02 separate Basements (storage), Ground floor plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/School/2022/SZ/448 dated 25.04.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 04.03.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Dr. Ved Tendon
10. Year of Construction : 2005-2006
11. Applicant's letter No. : Kmsss/2025/2121 dated 14.02.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 25.04.2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Old Case Old Case N/A	4.6 m 04 & 3.6 m N/A	MR, old case MR, old case N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	07 No's 02 No's in 1st basement & 01 no. in II nd basement	07 No's 02 No's in 1st basement & 01 no. in II nd basement	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	Old case 1.50 m	1.68, 1.47, 1.17, 1.12, 1.12 & .99 m (GF to III F) & 1.17 m (GF to FF) 1.65 & 1.65 m in 1st & .90 m in II nd	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Four	MR
	e. Width of Corridor	Old case	2.85, 1.63 & 1.14 m	MR, old case
	f. Door Size	1.0 m	1.0 m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	Required Required	Exhaust fans are provided Natural ventilation	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	45 no.'s ABC/CO ₂ type ISI marked	Provided Provided ISI marked	MR MR MR

1/24

6.	First-Aid Hose Reels			
	• Total numbers on each floor	04 no.'s	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	Two	N/A
	• Hose Box	N/A	Two	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	One	N/A
	• Hose Box	N/A	One	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	Old case	450 LPM & 180 LPM provided	MR, old case
	➤ Head of the pump	30 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	Old case	10000 ltrs Provided	MR, old case
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			No Lift
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

10/28

	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F6/DFS/MS/School/2022/SZ/448 dated 25.04.2022, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

D.O. (South/West)

5/4/25

CFD

6/8/2025

Director

7/10/24

ADP JKP

F-T helter & put up for sign' place

DIRECTOR

10/10/24

12/3/2025