



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/614

Dated: 07 / 08 / 2025

To

Smt. Pinki Yadav (Manager),
Kanak Public School,
Khasra No.988/1, Near Oberoi Farm,
Kapashera, New Delhi-110037

Sub: Renewal of Fire Safety Certificate in r/o Kanak Public School, Khasra No.988/1, Near Oberoi Farm, Kapashera, New Delhi-110037

Sir,

This has a reference to your letter No. KPS/345/25 dated 12/06/2025, received in this department vide outdoor diary No. 2703 dated 13/06/2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 18/07/2025 from fire safety point of view, in the presence of Smt. Anamika Yadav (Principal). During course of inspection, the shortcomings observed are as below.

1. The hose-reel hose found non-functional.
2. Terrace level fire pump was not on auto mode.
3. Exit signage found removed at some places.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.