



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2026/School/ 392

Dated: 27/04/2026

To,

Mrs. Punam (In-Charge),
Kapila Public School,
2, Sandesh Vihar, Pitampura,
Delhi-110034.

Sub: Issue of FSC in r/o M/s Kapila Public School, 2, Sandesh Vihar, Pitampura, Delhi-110034.

Sir,

Kindly refer to the letter received in this department vide Outdoor Diary No. 11294 dated 24.02.2026 on the subject cited above. In this connection, it is informed that the above-mentioned building was inspected by the officers concerned of this department on 21.04.2026 in the presence of Mrs. Punam (In-Charge). During the inspection, it was observed that the building comprises Ground plus two upper floors, and the school is operating on the first and second floors only.

The point-wise status is as under:-

Sr. No.	Shortcomings	Remarks
1.	One additional staircase having width at least 0.75m is required	(Not rectified) Provided but accessible through class room
2.	Terrace pump is provided but not functional.	Not complied
3.	Hose reel is provided but not functional	Not complied
4.	Capacity of overhead water tank is less than required capacity of 2500ltr	Not complied

Yours faithfully

27/04/26

(S.K.Dua)
Chief Fire Officer
Delhi Fire Service