



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आज़ादी का
अमृत महोत्सव

No. F6 /DFS/MS/EH/NDZ/2026/ 428

2/30
Dated: 06/05/2026

To

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Ref: elt.mcdonline application no. 2026040704534.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Karim Restaurant located at S-517,
School Block, Shakarpur, Delhi-92.

Sir,

In context to the application mentioned in reference, it is informed that the said restaurant was inspected by officer concerned of this department on 23/04/2026 in the presence of Mr. Vinod (Supervisor) and it was observed that the Restaurant is running on Ground floor of the building comprised of Basement + Ground + 03 upper floors. During the inspection the following shortcomings were observed.

1. Fire Check Door (FCD) found removed in kitchen.
2. Overhead water storage tank of 20,000 liters shall be provided against the existing tank of 10,000 liters.


In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


5/5/26

(Dr. S. K. Tomar)

Chief Fire Officer


04/5/26