

C-53



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
 आज़ादी का
 अमृत महोत्सव

No. F6/DFS/MS/EH/2025/52

Dated:- 13/02/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s. Karim Restaurant (A Unit of Siddiqui Hospitality), Located at Shop No. 12 & 14, Khasra No. 253, Village Sultanpur, MG Road, New Delhi-110030, comprised of ground floor only, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/EH/2019/SZ/557 dated 15/03/2019. The said premise was re-inspected by the officer concerned of this department on 04/02/2025 in the presence of Sh. Parveen (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" Group D with effect from 13/02/2025 and valid upto 31/03/2028 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 13/02/2025 at New Delhi by.

(Ajul Garg)
 Director

Tel. No. 011-23414000

Copy to: -

1. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi:- in r/o computer id no. 2025011600593 dated 16/01/2025
2. The Authorized Signatory, M/s. Karim Restaurant, Shop no. 12 & 14, Khasra No. 253, Village Sultanpur, MG Road, New Delhi-110030

Following fire safety certificate must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

Qc ac
 13/02/25

INSPECTION REPORT

1. Name & address of the building : M/s Karim Restaurant located at Shop No. 12 & 14, Khasra No. 253, Village Sultanpur, MG Road, New Delhi-110030
2. Type of Occupancy : Assembly, "Group-D"
3. Type of Case : Renewal, (Restaurant at Ground Floor)
4. Details of previous NOC : F6/DFS/MS/EH/2019/SZ/557 dated 15/03/2019
5. Fire Safety directives Letter No. : Approval of building parameters at N/2
6. Date of inspection : 04/02/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Parveen (Manager)
9. Year of Construction : 2017
10. Applicant's letter no. : 2025011600593 dated 16/01/2025

Minimum standards on fire prevention and fire safety U/R 33	NBC/UBBL-2016 Requirements	Provided at site	Remarks MR/NMR
Access of building			
• Road width	06 m	12 m	MR
• Gate width	NA	NA	NA
• Width of internal road	NA	NA	NA
Number, width, Type & Arrangements of exits			
a. Number of staircases			
• Upper floors	NA	Restt at GF only	NA
• Basements	NA	NA	NA
b. Width of staircases			
• Upper floors	NA	Restt at GF only	NA
• Basements	NA	NA	NA
c. Protection of exits			
• Fire check door	NA	NA	NA
• Pressurization	NA	NA	NA
d. No of continuous staircase to terrace	NA	01	NA
e. Width Of Corridor	NA	NA	NA
f. Door Size	2 m / 1.35 m	2 m & 1.52 m	MR
Compartmentation			
• Fire check door	NA	NA	NA
• Sealing of electrical shafts	NA	NA	NA
• Fire Rating of shaft door	NA	NA	NA
• Water Curtain	NA	NA	NA
• Fire Dampers	NA	NA	NA
Smoke managements System			
• Basements	NA	NA	NA
• Upper floors	Required	Provided	MR
Fire Extinguishers			
• Total numbers	Required	04 Nos.	MR
• Types	ABC & CO ₂	Provided	MR
• IS marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	Smoke & Heat	NA
	• Location of Main Panel	NA	Provided	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	Provided	NA
	• Hooters' Location	NA	All area	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	100 mm	NA
	• Number of hydrants per floor	NA	One	NA
	• Hose Box	NA	One	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings issued vide letter no. F6/DFS/MS/EH/2022/SZ/673 dated 22/11/2022 found rectified.

In view of the deemed compliance of minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/2019/SZ/557 dated 15/03/2019 is recommended under rule 37 of the Delhi Fire Service Rule, 2010 under DFS Act 2007.

Accordingly DFA is prepared & put up for approval please.

[Signature]
26/02/25
Aman Kumar Lathar
ADO (JWP)

[Signature]
20/03/25

[Signature]
10/02/25

[Signature]
10/02/25

[Signature]
10/02/25
Director

[Signature]
10/02/25
ADP/JWP

Sir, F.T. letter is put-up for your signature pl.

[Signature]
Director

[Signature]
13/02/25
ADD (JWP)

[Signature]
14/02/25
Q