

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/Court/NDZ/2026/335

Dated: 03 /08 /2026

To,

The Administration Officer,
O/0 Pr. District & Sessions Judge (East),
Karkardooma Court, Delhi – 110032.

Sub: - **Regarding Fire Safety Audit of Karkardooma Courts Complex, Block-A, C, I, D, E, F, G, and H, Shahdara, Delhi - 110032.**

Sir,

This has a reference to the letter no. 1396/CTB(E)/KKD/2026 dated 02/07/2026 on the subject cited above. In this regard, it is submitted that the inspection of the Block-A, C, I, D, E, F, G, and H, Karkardooma Courts Complex, was carried out by ADO (Shah.) on 18/07/2026 in the presence of Sh. Rishab Shukla (JE Elect/PWD) & Sh. Suraj Shah (JE Civil/PWD) and observed following shortcomings in the block A, C & I.

1. An additional first aid hose reel is required at Judge's chambers corridor.
2. Smoke management system is not provided in basement.
3. Fire Check Doors (FCD) not provided in the basement.
4. Alternate exit is obstructed in the basement.
5. Staircase, serving from basement is not segregated on ground floor.
6. MOEFA provided but found non-functional.
7. Firefighting system not provided in the basement.
8. Combustible material found stored in the basement.
9. Over head tank capacity 20,000 liters found damage.
10. Terrace pump 900 lpm provided but not functional.
11. Exit signage not provided in the building
12. Fire safety installation works were in progress in Blocks D, E, F, G, and H and not completed at the time of inspection.

Yours faithfully



(Dr. S. K. TOMAR)

CHIEF FIRE OFFICER

o/c DELHI FIRE OFFICER