

c/14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/EH/SZ/2026/ 326

Dated: 09/04/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Karnataka Food Center located at Delhi Karnataka Sangha Building, Ground Floor, Sector-12, Rao Tula Ram Marg, R. K. Puram, New Delhi - 110022 in a building comprises of Basement, Ground Plus Three Upper Floors owned/occupied by Delhi Karnataka Sangha was earlier issued FSC by this department vide letter No. F.6/DFS/MS/EH/2023/SZ/314 dated 30/06/2023. Now, the premises was re-inspected by the officer concerned of this department on 25/03/2026 in the presence of Mr. Sharif (Estate Manager) and found that the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant is fit for occupancy class "Assembly Building "Class - D" (Restaurant running at Ground floor only) with effect from 09/04/2026 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....09/04/2026.....at New Delhi by.


(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service
81476
86

Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, Dr. SPM Civic Center, Minto Road, New Delhi-110002. (Ref. online portal ID No 2026030502399 Dt. 06/03/2026).
2. The Manager, M/s M/s Karnataka Food Center located at Delhi Karnataka Sangha Building, Ground Floor, Sector-12, Rao Tula Ram Marg, R. K. Puram, New Delhi - 110022.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The trained firefighting staff should be available at the site round the clock.
6. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning authority.
7. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any. Basement shall be used as per BBL concerned.
9. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1.	Name & address of the building: -	M/s Karnataka Food Center located at Delhi Karnataka Sangha Building, Ground Floor, Sector-12, Rao Tula Ram Marg, R. K. Puram, New Delhi - 110022		
2.	Type of occupancy: -	Assembly Building "Group - D" (Eating House)		
3.	Building Comprised of: -	Basement, Ground Plus Three Upper Floors (Restaurant running at GF only)		
4.	Type of case: -	Renewal		
5.	Details of previous FSC No: -	F.6/DFS/MS/EH/2023/SZ/314 dated 30/06/2023		
6.	Fire safety directives No: -	F.6/DFS/MS/Bldg/2020/SZ/251 dated 16/07/2020 (Building NOC)		
7.	Date of inspection: -	25/03/2026		
8.	Name of the inspecting officer: -	Kaushal Kishore, ADO (SJ)		
9.	Name & designation of officer from the building side: -	Mr. Sharif (Estate Manager)		
10.	Year of construction: -	2005	Restt. is running at ground floor only	
11.	Applicant's letter No: -	Online Portal I.D. 2026030502399 Dt. 06/03/2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	9 m	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits	Restt. at ground floor only ✓		
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircase			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 exits	Provided	MR (Old Case)
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain (Basement)	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A

5.	Fire Extinguishers			
	• Total numbers	04 Nos.	05 Nos.	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	One	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors (Smoke)	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrant			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13.	Pumping Arrangement	Pumping arranging common with Building		
	Ground level			
	• Discharge of main pump	N/A	2850 LPM	N/A
	• Head of main pump	N/A	70m	N/A
	• Number of main pumps	N/A	01m	N/A
	• Jockey pump out put	N/A	180 LPM	N/A
	• Jockey pump head	N/A	70m	N/A
	• Stand by pump output	N/A	2850 LPM	N/A
	• Stand by pump head	N/A	70m	N/A
	• Auto starting/Manual stopping	N/A	Provided	N/A
	• Pump House Access	N/A	Provided	N/A
	Terrace level			
	• Discharge of pump	450 LPM	2 X 450 LPM	MR
	• Head of pump	40m	Provided	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	1,00,000 ltrs	N/A
	• Draw-off connection	N/A	Provided	N/A
	• Fire service inlet	N/A	Provided	N/A

	• Access to tank	N/A	Provided	N/A
	• Overhead tank capacity	10,000 ltrs	15,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/2023/SZ/314 dated 30/06/2023, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.** The last date of deemed approval is 03.04.2026 //

Accordingly, DFA is put up for approval & signature please.

Signature of the Inspecting Officer
Name: Kaushal Kishore
Designation: ADO (SJ)

DO (SD)

Ravinder Singh

A.K. MALIK

A.K. MALIK

my. cfo (SZ)

my. cfo to Secy.