

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/Hospital/NDZ/2025/ 333

Dated: 11/10/2025

To

The Medical Superintendent,
Kasturba Hospital, Dariya Ganj,
New Delhi -110002.

Sub: - Regarding renewal of 'Fire Safety Certificate' in r/o Kasturba Hospital, Main Building, Dariya Ganj, New Delhi-02.

Sir,

This has reference to email dated 13.06.2025 & outdoor diary No. 2804 dated 17.06.2025 on the subject cited above. In this connection, it is to inform you that the building /premises was visited by the officer concerned of this department on 20.06.2025 in the presence of Mr. Rahul (Elect. Staff) and it was observed that the building is comprised of basement + ground + 04 upper floors. During the inspection following shortcomings were observed:-

1. Door closure of fire check doors found removed.
2. Exhaust fans for ventilation were not provided in the basement.
3. First aid hose reel provided but non functional.
4. Automatic detection and alarm system (ADAS) provided but non functional. This arrangement shall also be extended to the left out areas.
5. Manually operated electrical fire alarm (MOEFA) system provided but not functional.
6. Public address system with talkback facility provided but not functional.
7. Automatic sprinkler system provided in basement but non functional.
8. Internal hydrant was non functional and landing valves were found removed at some floors. Delivery hoses and branches were also found removed.
9. Hydrant system was not provided on terrace.
10. Fire pumps at ground level and at terrace level found not functional.
11. Exit signages not adequately provided.
12. System panels provided but non functional.
13. Overhead cables, branches & other obstructions shall be removed near the entry gate.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Tel:-011-23414000

01/10/2025

Copy to:-

1. The Executive Engineer (Electrical),
Underground Car parking, Asaf Ali Road, New Delhi.