



No.F6/DFS/MS/School/SZ/2025/ 62

Dated: 24/01/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Kaviraj Khazan Chand Quetta DAV Sr. Sec. School** located at **Nizamuddin East, New Delhi-13**, comprised of Two Blocks: **A Block** - Ground + 01 upper floor & **B Block** - Ground + 01 upper floor was granted Fire Safety Certificate by this department vide letter no.- F.6/DFS/MS/School/2022/SZ/219 dated 28.02.2022. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 20.01.2025 in the presence of Mr. Arvind Kumar Sharma (HOS) and found that the school building has complied with the fire prevention and fire safety requirements in accordance with the circular no. 3298 to 3398 dated 01.03.2011 issued by the Directorate of Education and the building/premises is comprised of Two Blocks: (**A Block** - Ground + 01 upper floor & **B Block** - Ground + 01 upper floor) is fit for occupancy of Group B "**Educational Building**" with effect from .....24/01/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on...24/01/2025...at New Delhi by

(Atul Garg)  
Director  
Delhi Fire Service

**Copy to:-**

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Kaviraj Khazan Chand Quetta DAV Sr. Sec. School located at Nizamuddin East, New Delhi-13.

**Conditions for the validity of Fire Safety Certificate**

1. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.



2/12  
**INSPECTION REPORT**

|             |   |   |   |                       |
|-------------|---|---|---|-----------------------|
| <b>1</b>    | Name & address of the building                                    | Kaviraj Khazan Chand Quetta DAV Sr. Sec. School located at Nizamuddin East, New Delhi-13.                               |   |                       |
| <b>2</b>    | Building is comprised of  | Comprised of Two Blocks:<br>A Block - Ground + 01 upper floor<br>B Block - Ground + 01 upper floor                      |   |                       |
| <b>3</b>    | Type of occupancy   | Group B- Education Building (School)  |   |                       |
| <b>4</b>    | Type of case  | Renewal   |   |                       |
| <b>5</b>    | Details of previous FSC   | F.6/DFS/MS/School/2022/SZ/219 dated 28.02.2022  |   |                       |
| <b>6</b>    | Fire safety direction letter no.                                  | F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011   |   |                       |
| <b>7</b>    | Date of inspection  | 20.01.2025  |   |                       |
| <b>8</b>    | Name of the inspecting officers                                   | Rajesh Kumar Shukla, ADO (M. Road)  |   |                       |
| <b>9</b>    | Name of the designation of officer from the building side         | Mr. Arvind Kumar Sharma (HOS)   |   |                       |
| <b>10</b>   | Year of construction  | 1965 & 1980   |   |                       |
| <b>11</b>   | Applicant's letter no.  | Outdoor diary no. 11385 dated 14.01.2025  |   |                       |
| <b>S.No</b> | <b>Minimum standard of fire prevention and fire safety U/R 33</b> | <b>Requirement as per Rule 35 (6)</b>   | <b>Provided at site</b>                                 | <b>Remarks MR/NMR</b> |
| <b>1</b>    | <b>Access to Building:</b>  |   |   |                       |
|             | <b>A</b> Road width   | 9.0 m   | 9.0 m   | MR                    |
|             | <b>B</b> Gate width   | NA  | NA  | NA                    |
|             | <b>C</b> Width of internal road                                   | NA  | NA  | NA                    |
| <b>2</b>    | <b>Number, Width, Type and Arrangement of Exits:</b>              |   |   |                       |
|             | <b>A</b> Number of staircases                                     |   |   |                       |
|             | a Upper floor   | 01 no.  | A block - 2 nos.<br>B block - 2 nos.                    | MR                    |
|             | b Basement  | NA  | NA  | NA                    |
|             | <b>B</b> Width of staircases                                      |   |   |                       |
|             | a Upper floor   | 1 staircase of 1.5 mtrs or if main staircase width is < 1.5 mtrs an additional staircase of 0.75 mtrs width is required | A block - 1.08 m & 1.04 m.<br>B block - 1.23 m & 1.21 m | MR                    |
|             | b Basement  | NA  | NA  | NA                    |
|             | <b>C</b> Protection of exits                                      |   |   |                       |
|             | a Fire check door   | NA  | NA  | NA                    |
|             | b Pressurization  | NA  | NA  | NA                    |
|             | <b>D</b> No. of continuous staircases to terrace                  | 01 no.  | 01 no. in each block                                    | MR                    |
|             | <b>E</b> Width of corridor  | 1.50 m  | Provided  | MR                    |
|             | <b>F</b> Door size  | 1.0 mtrs. (for class rooms)   | Provided  | MR                    |
| <b>3</b>    | <b>Compartmentation:</b>  |   |   |                       |
|             | <b>A</b> Fire check door  | NA  | NA  | NA                    |
|             | <b>B</b> Sealing of electrical shafts                             | NA  | NA  | NA                    |
|             | <b>C</b> Fire rating of shaft door                                | NA  | NA  | NA                    |
|             | <b>D</b> Water curtain  | NA  | NA  | NA                    |
|             | <b>E</b> Fire dampers   | NA  | NA  | NA                    |
| <b>4</b>    | <b>Smoke Management System:</b>                                   |   |   |                       |
|             | <b>A</b> Basement   | NA  | NA  | NA                    |
|             | <b>B</b> Upper floor  | NA  | NA  | NA                    |
| <b>5.</b>   | <b>Fire Extinguisher:</b>   |   |   |                       |
|             | <b>A</b> Total numbers  | 06 nos.   | 08 nos.   | MR                    |
|             | <b>B</b> Types  | CO <sub>2</sub> & ABC   | CO <sub>2</sub> & ABC                                   | MR                    |
|             | <b>C</b> ISI marking  | ISI Marked  | Provided  | MR                    |
| <b>6</b>    | <b>First-Aid-Hose Reel:</b>                                       |   |   |                       |
|             | <b>A</b> Total numbers of each floor                              | NA  | NA  | NA                    |
|             | <b>B</b> Length of hose reel hose                                 | NA  | NA  | NA                    |
|             | <b>C</b> Nozzle diameter  | NA  | NA  | NA                    |

|    |  |                                |          |    |
|----|--|--------------------------------|----------|----|
| 7  | <b>Automatic Fire Detection and Alarming System:</b> |                                |          |    |
|    | A  | Type of detectors              | NA       | NA |
|    | B  | Location of main panel         | NA       | NA |
|    | C  | Location of repeater panel     | NA       | NA |
|    | D  | Alternate source of power      | NA       | NA |
|    | E  | Hooters                        | NA       | NA |
| 8  | <b>MOEFA:</b>  |                                |          |    |
| 9  | <b>Public Address System:</b>                        |                                |          |    |
| 10 | <b>Automatic Sprinkler System:</b>                   |                                |          |    |
|    | A  | Basement                       | NA       | NA |
|    | B  | Upper floor                    | NA       | NA |
|    | C  | Sprinkler above false ceiling  | NA       | NA |
| 11 | <b>Internal Hydrants:</b>                            |                                |          |    |
|    | A  | Size of riser/down-comer       | NA       | NA |
|    | B  | Number of hydrants per floor   | NA       | NA |
|    | C  | Hose box                       | NA       | NA |
| 12 | <b>Yard Hydrants:</b>                                |                                |          |    |
|    | A  | Total number of hydrants       | NA       | NA |
|    | B  | Hose box                       | NA       | NA |
| 13 | <b>Pumping Arrangements:</b>                         |                                |          |    |
| A  | <b>Ground level</b>                                  |                                |          |    |
|    | a)   | Discharge of main pump         | NA       | NA |
|    | b)   | Head of main pump              | NA       | NA |
|    | c)   | Number of main pumps           | NA       | NA |
|    | d)   | Jockey pump out put            | NA       | NA |
|    | e)   | Jockey pump head               | NA       | NA |
|    | f)   | Standby pump out put           | NA       | NA |
|    | g)   | Standby pump head              | NA       | NA |
|    | h)   | Auto starting /manual stopping | NA       | NA |
|    | i)   | Pump house access              | NA       | NA |
| B  | <b>Terrace Level</b>                                 |                                |          |    |
|    | a)   | Discharge of pump              | NA       | NA |
|    | b)   | Head of the pump               | NA       | NA |
|    | c)   | Power supply                   | NA       | NA |
|    | d)   | Auto starting of pump          | NA       | NA |
| 14 | <b>Captive Water Storage for Fire Fighting:</b>      |                                |          |    |
|    | A  | Underground tank capacity      | NA       | NA |
|    | B  | Draw-off connection            | NA       | NA |
|    | C  | Fire service inlet             | NA       | NA |
|    | D  | Access to tank                 | NA       | NA |
|    | E  | Overhead tank capacity         | NA       | NA |
| 15 | <b>Exit Signage:</b>                                 |                                |          |    |
|    |  | Required                       | Provided | MR |
| 16 | <b>Provision of Lifts:</b>                           |                                |          |    |
|    | A  | Pressurization of lift shaft   | NA       | NA |
|    | B  | Pressurization of lift lobby   | NA       | NA |
|    | C  | Communication in lift car      | NA       | NA |
|    | D  | Firemen's grounding switch     | NA       | NA |
|    | E  | Lift signage                   | NA       | NA |
| 17 | <b>Standby Power Supply:</b>                         |                                |          |    |
|    |  | NA                             | NA       | NA |
| 18 | <b>Refuge Area:</b>                                  |                                |          |    |
|    | A  | Total area                     | NA       | NA |
|    | B  | Location                       | NA       | NA |



2/19

Kaviraj Khazan Chand Quetta DAV Sr. Sec. School located at Nizamuddin East, New Delhi-13.

|    |   |                       |    |    |
|----|---|-----------------------|----|----|
| 19 | <b>Fire Control Room:</b>   |                       |    |    |
|    | A   | Detector system panel | NA | NA |
|    | B   | Flow switch panel     | NA | NA |
|    | C   | PA system panel       | NA | NA |
|    | D   | Battery backup        | NA | NA |
|    | E   | Building floor plans  | NA | NA |
| 20 | <b>Special Fire Protection systems for protection of special Risks, if any:</b> |                       | NA | NA |

**LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education circular no. 3298 to 3398 dated 01.03.2011, the FSC issued vide letter no. F.6/DFS/MS/School/2022/SZ/219 dated 28.02.2022 is recommended to be renewed.

Signature of the Inspecting Officer  
Name Rajesh Kumar Shukla  
Designation ADO (M. Road)

DO (SP)

C. S. (S. S.)

Director