



C 31   
ॐ नमो भगवते वासुदेवाय

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No.F.6/DFS/MS/EH/SZ/2025/434

Dated: 17/11/2025

To,

Mrs. Beeban Arora,  
M/s K.C. Hospitality located at J-2/12, First Floor,  
Rajouri Garden,  
New Delhi-110027

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s K.C. Hospitality located at J-2/12,  
First Floor, Rajouri Garden, New Delhi-110027.**


Sir,

This has reference to MCD application ID No. 2024090913986 dated 18/10/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 08/11/2025 in presence of Sh. R. K. Arora. The premises is comprised of ground plus three upper floors but restaurant is running first floor only. The following shortcomings were observed during the time of inspection.

1. First-Aid Hose reel is provided but not functional at the time of inspection.
2. MOEFA provided but not functional.
3. Down-comer provided but not functional.
4. Terrace pump provided but not functional.
5. Lift not in use. which either should be closed or isolated as undertaking submitted by the manager.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
17/11/25  
(A. K. MALIK)

o/c  
2.  
DY. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE