



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2025/ 448

Dated: 26/05/2025

To

The Principal,
Khadliatul Kubra Girls Public School,
8/1, Joga Bai, Jamia Nagar, New Delhi-25.

Sub:- Regarding issuance of Fire Safety Certificate in r/o **Khadliatul Kubra Girls Public School** located at **8/1, Joga Bai, Jamia Nagar, New Delhi-25.**

Sir,

With reference to the letter bearing outdoor diary no. 1439 dated 07.05.2025 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 19.05.2025 in the presence of Mr. Talha (Manager) and following shortcomings were observed:-

1. No alternate exit at Ground floor in Sr. block.
2. First aid hose reels not provided in Jr. block & found non functional in Sr. block.
3. Fire pump found non functional.
4. Exit signage has not been adequate.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Ansh Garg)
Director
Delhi Fire Service

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.