

Chio

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ EH / 25

Dated:- 17/01/2025

To,

The Manager  
M/S Khalsa Parivar Restaurant,  
G-1, G-2, G-3, Ground floor, 12 DDA,  
Facility Centre Mayapuri PH-II, Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Khalsa Parivar Restaurant,  
G-1, G-2, G-3, at Ground floor, 12 DDA, Facility Centre Mayapuri PH-II, Delhi.**

Sir,

This has reference to online ID No. 2024122318292 dated 23/12/24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 11/01/25 in the presence of Mr. Rohit and following shortcomings were observed:-

1. Alternate exit found blocked.
2. Pump found nonfunctional.
3. Over head tank of 10,000 liter is provided against the requirement of 20,000 liter.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Gang)  
DIRECTOR  
Delhi Fire Service

Copy to:

1. The Joint commissioner of Police ( Lic.) First floor , PS Defence Colony New Delhi.