



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/2025/School/ 02

Dated: 03/01/2025

FIRE SAFETY CERTIFICATE

Certified that the **Monarch Public School** located at **Khasra No-92/20, B-Block, Baba Colony, Burari, Delhi-110084** comprised of **Ground & 02 upper floors only** owned/ occupied by **Monarch Public School** was issued Fire Safety Certificated vide this office letter no. **F6/DFS/MS/School/2022/WZ/20 dated 06.01.2022**. The premise was inspected by the officer concerned of this department on **28.12.2024** in the presence of **Sh. Chandra Shekhar Yadav (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **"Educational Group B (School)"** with effect from 03/01/2025 for a period of **three years**, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 03/01/2025 at New Delhi

(Atul Garg)
 Director

Ph:-011-23414000

Copy to: -

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.
2. The Principal, Monarch Public School located at KH. No-92/20, B-Block, Baba Colony, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".
8. This Fire Safety Certificate is valid ground & 02 upper floors for educational occupancy only. If any additional construction temporary or permanent is made in future, the Fire Safety Certificate will be treated as null & void.

INSPECTION REPORT

1. Name & address of the building : Monarch Public School, Kh. no. 92/20, B-block, Baba Colony, Burari, Delhi-84.
2. Composition of building : Ground & 02 upper floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2022/WZ/20 dated 06.01.2022
6. Fire Safety directives letter No : NBC Part-4
7. Date of inspection : 28.12.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. Chandra Shekhar Yadav (Manager)
10. Year of Construction : 2010/2012
11. Applicant's letter No. : Online E-Mail dated 18.12.2024

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-4 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
		06m	06m	MR
	• Road width	Directly Accessible	Directly Accessible	MR
	• Gate width			
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m each & 1.25m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	01m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	08 nos	10nos	MR
	• Types	ABC/CO2	ABC—08/Co2-02	MR
	• ISI marking	ISI Marked	Yes	MR

by  


6	First-Aid Hose Reels.			
	<ul style="list-style-type: none">• Total numbers on each floor• Length of hose reel hose• Nozzle diameter	01	Provided	M
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none">• Type of detectors• Location of Main Panel• Location of Repeater Panel• Alternate source of power• Hooters' Location	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none">• Basement• Upper Floor• Sprinkler above false ceiling	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 LPM	450 LPM	MR
		40m	40m	MR
	Required	Provided	MR	
	Required	Provided	MR	
	14	Captive Water Storage for fire fighting.		
<ul style="list-style-type: none">• Underground tank capacity<ul style="list-style-type: none">➤ Draw-off connection➤ Fire service inlet➤ Access to tank• Overhead Tank capacity		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 LTR	Provided	MR

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.


Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by NBC Part-IV, the FSC issued vide letter of even no. F6/DFS/MS/School/2022/WZ/20 dated 06.01.2022 renewal under rule 37 of the Delhi Fire Service Rules, 2010.

D.B. Mukharjee (DO/NW)


30/12/2024
Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

88/1112
Dated 30/12/2024


30/12/2024
By Cfo (WZ)


30/12/2024

Cfo
31/12/2024
Director



cont - P.T.O.