

C6

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F.6 DFS/MS/School/2025/WZ/1342

Dated: 26/11/2025

FIRE SAFETY CERTIFICATE

Certified that the Ch. Khushiram Public School located at Kh. No 19/19, F- Block, Inder Enclave Phase-2, Main Mubarikpur Road, Near Roop Chand Hospital, Delhi 110086 Comprised of Ground and First Floor owned/occupied by Jit Singh Foundation was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/WZ/297 dated 06/02/2019. The said premises was inspected by officer concerned of this department on 14/11/2025 in presence of Mr. Naveen Dabas and observed that all the fire safety arrangement as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Directorate of Education vide letter no 3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "Educational Building Group - B" with effect from26/11/2025 for a period of three years subject to compliance of the conditions mentioned below.

Issued on26/11/2025.....at New Delhi by


S.K. Dua 26/11/25
Dy. Chief Fire Officer (WZ)
Delhi Fire Service
o/c Ch.

Copy to: -

1. The Principal, Ch. Khushiram Public School located at Kh. No 19/19, F- Block, Inder Enclave-2, Main Mubarikpur Road, Delhi 110086.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Ch. Khushiram Public School at Kh. No-19-19, F-Blk, Inder Enclave-2, Main Mubarik Pur Road, Near Roop Chand Hospital, Delhi-110086.
2. Type of Occupancy : Educational
3. Composition of building : Ground & First Floor Only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2019/WZ/297 Dated: 06/02/2019
6. Fire Safety directives letter No : Nil
7. Date of inspection : 14/11/2025
8. Name of the Inspecting Officers : ADO (Rohini)
9. Name and designation of officers from the building side : Mr. Naveen Dabas
10. Year of Construction : 2016/17
11. Applicant's letter No. : Letter No. CKRPS/Nov/2025 Dated- 06/11/2025

	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular dated 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	Provided	MR
	• Gate width	4.50m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	01m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	04nos	05nos	MR
	• Types	ABC/CO2	ABC—05	MR
	• ISI marking	ISI Marked	Yes	MR

6	First-Aid Hose Reels.		
	• Total numbers on each floor	NA	NA
	• Length of hose reel hose	NA	NA
	• Nozzle diameter	NA	NA
7	Automatic fire detection and alarming system.		
	• Type of detectors	NA	NA
	• Location of Main Panel	NA	NA
	• Location of Repeater Panel	NA	NA
	• Alternate source of power	NA	NA
	• Hooters' Location	NA	NA
8	MOEFA	NA	NA
9	Public Address System.	NA	NA
10	Automatic Sprinkler System.		
	• Basement	NA	NA
	• Upper Floor	NA	NA
	• Sprinkler above false ceiling	NA	NA
11	Internal Hydrants		
	• Size of riser/down-comer	NA	NA
	• Number of hydrants per floor	NA	NA
	• Hose Box	NA	NA
12	Yard Hydrants.		
	• Total number of hydrants	NA	NA
	• Hose Box	NA	NA
13	Pumping Arrangements.		
	• Ground Level		
	➤ Discharge of main Pump	N/A	N/A
	➤ Head of Main pump	N/A	N/A
	➤ Number of main pumps	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A
	➤ Jockey pump head	N/A	N/A
	➤ Standby Pump out put	N/A	N/A
	➤ Standby Pump Head	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A
	➤ Pump House Access	N/A	N/A
	• Terrace level		
	➤ Discharge of pump	N/A	N/A
	➤ Head of the pump	N/A	N/A
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	NA	NA
	➤ Draw-off connection	NA	NA
	➤ Fire service inlet	NA	NA
	➤ Access to tank	NA	NA

10/6

	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, **it is recommended for renewal of fire safety certificate** issued vide this department letter of even no. F6/DFS/MS/School/2019/WZ/297 Dated: 06/02/2019.

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO (Rohini)

DO/NW

By CFO (NOZ) on leave

By CFO (NOZ)

Principal Director

By. CFO to School.

By. CFO (NOZ)

19/11/25

19/11/25