



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6 /DFS/MS/Banquet Hall/NDZ/2026/24

Dated: 21.01.2026

To

The Commissioner,  
MCD, 9th floor, Civic Centre,  
Minto Road, New Delhi.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s King Courts Party Hall and Restaurant located at Vikas Cine Mall, 813/1, G.T. Road, Shahdara, Delhi.

Sir,

This has reference to the etl.mcdonline application no. 2025121515754 on the subject cited above. In this connection it is informed that the said Banquet Hall was inspected by officer concerned of this department on 13.01.2026 in the presence of Sh. Gopal Singh, Supervisor and it was observed that the Banquet Hall is running at 2<sup>nd</sup> floor of the building Vikas Cine Mall which is comprised of 03 tier Basement + Ground + 04 upper floors which has already been issued Fire Safety Certificate vide letter no. F6/DFS/MS/2023/NDZ/86 dated 15.02.2023. During the inspection the following shortcomings were observed:

1. Automatic Fire Detection and Alarm System (ADAS) found not provided.
2. Manually Operated Electrical Fire Alarm (MOEFA) found not provided.
3. Pressurization system of staircase found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Dr. S.K. Tomar)

Dy. Chief Fire Officer (NDZ)  
Delhi Fire Service

o/c DFO  
16/1/26