

C/37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/MN/Metro/2025/160

Dated: 03/04/2025

FIRE SAFETY CERTIFICATE

Certified that the Kirti Nagar, Metro Station (Line No. 03), located at Kirti Nagar, New Delhi, comprised of Ground + Concourse & Platform (Except PD Area), was issued FSC vide Letter No. F6/DFS/MS/2022/151 dated 05/04/2022. The premises was re- inspected by the officer concerned of this department on 21/03/2025 in the presence of Sh. Sudhanshu Mudgal (Sr. Fire Inspector) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" (Group-D) sub Division D- with effect from 03/04/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 03/04/2025 at New Delhi by.

(Atul Garg)
Director

Copy to: -

1. Sh. Vivek Srivastava (JGM/E&M), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations/ Addition & Alteration w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per BBL-1983.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. All Exits & Passage lead to ground should be kept from any obstruction.

INSPECTION REPORT

1.	Name & address of the building	Kirti Nagar, Metro Station (Line No. 03), Located at Kirti Nagar, New Delhi.
2.	Type of Occupancy	Assembly
3.	Type of Case	Renewal (Ground, Concourse & Platform) (Except PD Area)
4.	Details of previous NOC	F6/DFS/MS/2022/151 dated 05/04/2022
5.	Fire Safety directives letter No	F6/DFS/MS/BP/2004/2745 dated 11/11/04
6.	Date of inspection	21/03/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. Sudhanshu Mudgal (Sr. Fire Inspector)
9.	Year of Construction	2005 (As per previous Inspection Report dated 25/03/2022)
10.	Applicant's letter No.	Outdoor dairy No. 13021 dated 20/02/2025

The said building comprised of Ground, Concourse & Platform (Except PD Area).

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	On Main Road 05 mtr NA	Provided On Main Road NA	MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02	Provided	MR
	<ul style="list-style-type: none"> Upper Floors Basements 	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	1.5 m	2x410 cm, to each P.F. 1x370 cm, 1x165 cm G to C	MR(old case)
	c. Protection of exits	NA	NA	NA
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	Old Case	Provided	MR
	g. Door Size	2 m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required Required Required NA NA	Provided Provided Provided NA NA	MR MR MR NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	NA NA	NA NA	NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	35 nos. CO ₂ , ABC type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	2 (at each PF) 30 mts 05 mm	Provided Provided Provided	MR MR MR

88

7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	02 (on each PF)	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	02	Provided	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements.			
	• Ground Level	All the pumps are connected are generator also		
	➤ Discharge of main Pump	1800 LPM	Provided	MR
	➤ Head of Main pump	60m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	60m	Provided	MR
	➤ Standby Pump out put	1800 LPM	Provided	MR
	➤ Standby Pump Head	60m	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	50,000 ltrs	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	NA	10,000 ltr provided	NA
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

N/23

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Co2 Flooding for ASS, HT & LT Pannel	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/2022/151 dated 05/04/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

09/ADO/MN
24/03/2025

~~24/03/2025~~

~~24/3/2025~~

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

DCFO/9593-KDD
Dated: 27-03-25

~~27/3~~
~~CFO~~
~~28/3/2025~~
~~Director~~
~~for your personal & sig. p/s.~~
~~Director~~

for R.T. is put up
01/04/2025