

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001

C/121

No. F6/DFS/MS/WZ/2025/ 424

Dated: 27/08/2025

To,

The Authorized Signatory,
KLJ Tower, (Prithvi Company Private Limited),
B-5, Netaji Subash Place,
Pitampura, New Delhi-110034.

Sub: - Regarding renewal of Fire Safety certificate in r/o M/s. KLJ Tower, (Prithvi Sound Products Company Private Limited) Located at B-5, Netaji Subash Place, Pitampura, New Delhi-110034.

Sir,


Please refer to your Letter Nil dated Nil, received through outdoor diary No. 3801 dated 16/07/2025, of this department on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 11/08/2025 in the presence of Sh. D.P. Vashist to see the functioning of fire safety equipments provided in the Building.

During inspection, it has been observed that the above said building is comprised of basement, ground & thirteen upper floors, was issued FSC Vide letter No. F6/DFS/MS/WZ/2022/294 dated 04/07/2022. Fire safety arrangements such as Fire Extinguishers, MOEFA, First Aid hose reels, Over Head water storage tank, Underground water tank capacity, Pumping Arrangements etc are provided. However the following shortcomings was observed: -

1. Fire check doors found removed at some places.

In view of above, application for renewal of Fire safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours Faithfully,



Virendra Singh
Chief Fire Officer

Copy To:-

1. The Executive Engineer (Bldg.) HQ, North Delhi Municipal Corporation, 8th floor, Minto Road, New Delhi- 110002.
2. The Vice Chairman, DDA, INA, Vikas Sadan, New Delhi-110023.