



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F6/DFS/MS/WZ/2026/ 107

Dated: 10/04/2026

To,

The Medical Superintendent,
Nav Konarc Hospital,
J-1, RBI Enclave, Outer Ring Road,
Paschim Vihar, New Delhi – 110041

Sub: - Surprise inspection report in r/o M/s Nav Konarc Hospital located at J-1, RBI Enclave, Outer Ring Road, Paschim Vihar, New Delhi – 110041.

Sir,

As per directions of the Competent Authority vide office order no. F6/DFS/HQ/2026/494 dated 20/03/2026, it is to inform you that the surprise inspection of above said Hospital building has been carried out by the officer concerned on 30.03.2026 to verify the compliance of the requisite fire safety measures installed in the building, Mr. Kuldeep (Admin/HR) was present at the time of inspection. During the visit following observation were noticed:-

1. Smoke management system in basement found removed.
2. Terrace level pump not found in auto mode.
3. Exit Signage found removed at some places.

You are advised to rectify the above-mentioned shortcomings under intimation to this department, till than the occupancy of the Building/ Premise in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours Faithfully

S.K. Dua

Dy. Chief Fire Officer (WZ)
Delhi Fire Service