

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2025 / School / WZ / 647

Dated 13/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Krishan Dev Model School** located at **Bajitpur Thakran, Delhi-110039** comprised of Ground floor only was issued FSC by this department vide letter No F6 /DFS/MS/2022/School/WZ/324 dated 29.03.2022. The premises was re-inspected by the officer concerned of this department on 02.05.2025 in the presence of Sh. Pradeep Kumar (Manager), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from 13/05/2025 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 13/05/2025 at New Delhi by

(Atul Garg)

Director

Ph. 011-23414000

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. The Principal, Krishan Dev Model School located at Bajitpur Thakran, Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Krishan Dev Model School located at Bajitpur Thakran, Delhi-110039.
2. Type of Occupancy : Educational
3. Building Comprised of : Ground floor only.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2022/School/WZ/324 dated 29/03/2022
6. Fire Safety directives letter No : DOE circular No. 3298-3398 dated 01/03/2011
7. Date of inspection : 02/05/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Sh. Pradeep Kumar (Manager)
10. Year of Construction : 2009
11. Applicant's letter No. : Outdoor Diary No. 336 dated 08/04/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	Road width	6 m	Provided	MR
	Gate width	4.5 m	Directly Accessible	MR
	Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	Number of staircases			
	Upper Floors	NA	NA	NA
	Basements	NA	NA	NA
	Width of staircases			
	Upper Floor	NA	NA	NA
	Basements	NA	NA	NA
	Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	NA	NA	NA
	Width of Corridor	NA	NA	NA
	Door Size	1 m	Provided	MR
3.	Compartmentation			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	Basements	NA	NA	NA
	Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	Total numbers	03	Provided	MR
	Types	ABC Type	Provided	MR
	IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	Total numbers on each floor	NA	NA	NA
	Length of hose reel hose	NA	NA	NA
	Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA

N-19

8.	MOEFA	NA	NA	
9.	Public Address System	NA	NA	
10.	Automatic Sprinkler System			
	Basement	NA	NA	NA
	Ground Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	Size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12.	Yard Hydrants			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	Ground Level			
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	NA	NA	NA
	Head of the pump	NA	NA	NA
	Power Supply	NA	NA	NA
	Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire Control Room			
	Detector System Panel	NA	NA	NA

NA	NA	NA	NA
NA	NA	NA	NA
NA	NA	NA	NA
NA	NA	NA	NA
NA	NA	NA	NA
NA	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DPS/MS/2022/School/WZ/324 dated 29/03/2022.

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

Do (WZ)
06/05/2022

Dy Cfo (WZ)

07/05/2022

DCFO/1396-NW
dated 07/05/22

CFO/19/5/2022

Director/19/5/22

8m, P7 letter is PAF for you please

Director/19/5/22

13/5/22