

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.


No. F.6/DFS/MS/School/2025/SZ/1238

Dated: 08/10/25

FIRE SAFETY CERTIFICATE

Certified that the Krishna Model Secondary School located at Old Roshan Pura Extn., Najafgarh, New Delhi-110043, comprised of ground floor plus three upper floors owned/occupied by the Krishna Model Secondary School was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2022/SZ/1032 dated 20.09.2022. The school building was re-inspected by the officer concerned of this department on dated 26.09.2025 in the presence of Sh. Pankil Yadav (Manager), and found that the school building have complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (ground plus three upper floors) is fit for occupancy class "Educational Building" w.e.f. 08/10/25 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 08/10/25 at New Delhi by.


(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Krishna Model Secondary School located at Old Roshan Pura Extn., Najafgarh, New Delhi- 110043.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Krishna Model Secondary School, Old Roshan Pura Extn., Najafgarh, New Delhi-110043.
2. Building comprised of : Ground plus three upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/1032 dated 20.09.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 26.09.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers : Sh. Pankil Yadav (Manager)
- From the building side : Before 2009
10. Year of Construction : Form 'J' dated 12.09.2025
11. Applicant's letter No. :

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dated 20.09.2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 m 4.5 m N/A	06 m 4.5 m N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 No N/A	02 No's N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 & .75 m N/A	1.33 m & 1.42 m N/A	M/R, old case N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required	One	M/R
	f. Door Size	1.50 m	2.0 m	M/R
		1.0 m	1.05 m	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	03 no's/floor ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 nos. 30 M 5 mm	Provided Provided Provided	M/R M/R M/R


N/15


7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		450 LPM	450 & 180 LPM provided	MR
		30 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
		No Lift		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

standby power supply		N/A	N/A	N/A
Refuge Area.		N/A	N/A	N/A
➤ Total Area		N/A	N/A	N/A
➤ Location		N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
• Detector System Panel		N/A	N/A	N/A
• Flow Switch Panel		N/A	N/A	N/A
• PA System Panel		N/A	N/A	N/A
• Battery backup		N/A	N/A	N/A
• Building Floor Plans		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2022/SZ/1032 dated 20.09.2022 is **recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.


Signature of the Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)


DO (SW) 
29/9/25


Dy. C.F.O. (SZ)



11/10/25
A.K. MALIK

Principal/In-charge

F.T. pleau


11/10/25
A.K. MALIK

DO (SW) 
21/10/25
A.D.O. R.K. Yadav

Dy. C.F.O. (SZ) 
01/10/25