

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/School/2025/SZ/167

Dated: 24./03/2025

To

The Principal,  
K.S.M Public School,  
G-569, Kh. No 1540 min, Adarsh Enclave,  
Aya Nagar, Ext. Phase-6, Aya Nagar,  
New Delhi 110047.

Sub: Regarding issuance of FSC in r/o M/s K.S.M Public School, at G-569, Kh. No 1540 min, Adarsh Enclave, Aya Nagar, Ext. Phase-6, Aya Nagar, New Delhi 110047.

Sir,

This has reference with letter received through outdoor diary no 14062 dated 04/03/2025 on the subject cited above. In this connection, it is inform you that the premise have been inspected by officer concerned of this department on 18/03/2025 in the presence of Ms Anita Thapa (Teacher) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. The building is situated at Dead end road / closed road and the building is not accessible for fire engine / fire tender.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE