



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5  
आज़ादी का  
अमृत महोत्सव  
21/09

No. F6/DFS/MS/Hospital/NDZ/2025/ 88

Dated 04/03/2025

To,

Dr. H.S. Kukreja,  
Kukreja Hospital,  
D-36, Acharya Niketan Mayur Vihar Phase-1,  
Delhi-110091.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Kukreja Hospital at D-36, Acharya Niketan Mayur Vihar Phase-1, Delhi-110091.**

Sir,

This has a reference to your outdoor diary letter No. 11941 dated 29/01/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 21/02/2025 to ascertain the availability and operability of fire Safety measures laid down in BBL in the presence of Dr. H.S. Kukreja (Owner) and observed that building comprised of Basement + Ground + three upper floors only.

**Following shortcomings were observed during time of inspection:**

1. Fire pump of capacity 1620 LPM (electrical) one diesel pump of capacity 1620 LPM and one Jockey pump of 180 LPM are not provided.
2. Under ground water storage tank of 50,000 Ltr. not provided.
3. Exit signage/Lift signage not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg), Municipal Corporation of Delhi, Plot No.419, Patparganj Industrial Area, Delhi-110092.