



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C/21



No: F.6/DFS/MS/2025/WZ/ 595

Dated: 14/07/2025

To,

The Principal,
Kulachi Hansraj Model School (Nursery),
H-Block, Phase-1, Ashok Vihar,
Delhi-110052.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Kulachi Hansraj Model School (Nursery) located at H-Block, Phase-1, Ashok Vihar, Delhi- 110052.

Sir,

This has reference to your Form J received through outdoor diary no. 3045 dated 24/06/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 07.07.2025 to see the compliance of the existing fire safety measures. Sh. Rakesh Kumar was present at the time of inspection.

During the course of inspection it was observed that the school building comprised of Ground plus two upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels found provided but not functional
2. Terrace level pump found provided but not functional.
3. Exit signage's found removed at some places.
4. Electrical panel inside the corridor has to be removed to a safer place or been segregated.

5. Temporary rooms at terrace shall be removed.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Anil Garg)
Director

Ph 011-23414000

Signature
10/7/25

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.