



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/39



No: F.6/DFS/MS/2025/WZ/ 712

Dated: 09/09/2025

To,

The Principal,
Kulachi Hansraj Model School,
Phase-3, Ashok Vihar,
Delhi-110052.


Sub: - Regarding renewal of Fire Safety Certificate in r/o Kulachi Hansraj Model School located at Phase-III, Ashok Vihar, Delhi- 110052.

Sir,

This has reference to your Form-J received through outdoor diary no. 4394 dated 01/08/2025 on the subject cited above. In this connection, it is to inform you that the above said school building was visited by the officer concerned of this department on 25.08.2025 to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/2025/WZ/593 dated 14/07/2025. Sh. Rakesh Kumar was present at the time of visit. During the course of visit it was observed that shortcomings communicated via above mentioned letter were not rectified yet.

In view of the above, the application for renewal of Fire Safety Certificate can not be considered at this stage & rejected. You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully


8/9/2025

(Virendra Singh)
Chief Fire Officer



Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

Dated: 14/07/2025

No: F.6/DFS/MS/2025/WZ/593

To,

The Principal,
Kulachi Hansraj Model School,
Phase-3, Ashok Vihar,
Delhi-110052.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Kulachi Hansraj Model School located at Phase-III, Ashok Vihar, Delhi- 110052.

Sir,

This has reference to your Form J received through outdoor diary no. 3044 dated 24/06/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 07.07.2025 to see the compliance of the existing fire safety measures. Sh. Rakesh Kumar was present at the time of inspection.

During the course of inspection it was observed that the school building comprised of Basement, Ground plus three upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels found provided but not functional, hose reel pipe and nozzle found missing at some places.
2. P.A. system found provided but not functional.
3. Terrace level pump not found in auto mode.
4. Overhead tank of 15,000 ltrs capacity found provided against the required capacity of 20,000 ltrs.
5. Exit signage's found removed at some places.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Anil Garg)
Director

Ph. 011-23414000

ou n k
10/7/25

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.