



0120

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/2025/WZ/592

Dated: 14/07/2025

To,

The Principal,
Kulachi Hansraj Model School (Primary),
A-Block, Phase-1, Ashok Vihar,
Delhi-110052.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Kulachi Hansraj Model School (Primary) located at A-Block, Phase-1, Ashok Vihar, Delhi- 110052.

Sir,

This has reference to your Form J received through outdoor diary no. 3043 dated 24/06/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 07.07.2025 to see the compliance of the existing fire safety measures. Sh. Rakesh Kumar was present at the time of inspection.

During the course of inspection it was observed that the school building comprised of 02 Blocks (Ground plus two upper floors). Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels found provided but not functional and nozzle found missing at some places.
2. P.A system found provided but not functional.
3. Terrace level pump not found in auto mode.
4. Exit signage's found removed at some places.
5. Temporary rooms above ground floor block interconnected with block-2 shall be removed.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

10/7/25

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.