

C-36



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001





No. F6/DFS/MS/2025/Incl./ 468

Dated: 09/09/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Kumar Industries located at Plot No. A-31, G.T. Karnal Road, Industrial Area, Delhi-110033 comprised of basement, ground with double height & 02 upper floors but (industries is running in basement, ground with double height & first floor only) owned/occupied by M/s Kumar Industries was issued Fire Safety Certificate by this department vide office letter no. F6/DFS/MS/2022/Incl./563 dated 13/12/2022. The premises was inspected by the officer concerned of this department on 21/08/2025 in the presence of Sh. Munit Kumar and observed that all the fire prevention and fire safety arrangements as provided found in good working condition and the premises have deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class "G-2 Industrial building for basement, ground with double height & first floor only" with effect from 09/09/2025 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/09/2025 at New Delhi


 09/09/2025
 Virendra Singh
 Chief Fire Officer
 Delhi Fire Service


Copy to :-

1. M/s Kumar Industries located at Plot No. A-31, G.T. Karnal Road, Industrial Area, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. Basement shall not be used for any other purpose except as specified in UBBL, subject to permission from concerned local authority.
7. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Kumar Industries, Plot No.A-31, G.T.K. Road, Industrial Area, Delhi-33.
 2. Type of Occupancy : Industrial Building
 3. Composition of building : Industry running at basement, ground with double height + one upper floors only & second floor one hall is use for servant purpose only
 4. Type of Case : Renewal
 5. Details of previous NOC : F6/DFS/MS/2022/Indl./563 dated 13/12/2022
 6. Fire Safety directives letter No : F6/DFS/MS/BP/2006/1760 dated 28/07/2006
 7. Date of inspection : 21/08/2025
 8. Name of the Inspecting Officers : ADO(RN)
 9. Name and designation of officers from the building side : Sh. Munit Kumar
 10. Year of Construction : Prior to 2004
 11. Applicant's letter No. : Letter No. Nil dated: 18/07/2025

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per directives dated 28/07/06	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	18m	MR
	• Gate width	05m	06m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02	02	MR
	• Upper Floors	02	02	MR
	• Basements			
	b. Width of staircases	1.25m	1.50m & 1.10m	MR (being old case)
	• Upper Floors			
	• Basements	1.25m	02 nos. of 1.60m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.25m	Provided	MR
3	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Exhaust fan provided	MR
	• Upper floors	Required	Exhaust fan provided	MR
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types ISI marking 	20no's	20no's	MR
		ABC/CO2	ABC-16/CO2-04	MR
		ISI Marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Smoke/ Heat	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Ground floor	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Every floor	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	02nos	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	180 LPM	180 LPM	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	40m	40m	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	900 LPM (Diesel Operative)	900 LPM (Diesel Operative)	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	40m	40m	MR

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	Required	Provided	MR
		900 LPM	900 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50,000 LTR	50,000 LTR	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 LTR	10,000 LTR	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A