

C/107



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F.6/DFS/MS/EH/2025/SZ/ 09

Dated: 06/01/2025

To

The Joint Commissioner of Police (Licensing)  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s L'Opera (French Bakery Pvt Ltd) 13, Alipur Road, Civil Lines, Delhi -110054

Sir,

This has reference with **MCD Portal 2024121718098 dated 17/12/2024** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 30/12/2024 in the presence of Mr. Nitin (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. First Aid Hose Reel provided but found nonfunctional.
2. Automatic Sprinkler System found non functional.
3. Internal hydrant provided but found non functional.
4. Fire fighting pumps capacity 450 LPM & 180 LPM provided but found non functional.
5. Overhead tank capacity 5000 letters provided against the required capacity of 10,000 ltrs.
6. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

4-1-25  
31