

255

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F.6/DFS/MS/GH/2025/SZ/57

Dated: 29/01/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s **La-Vista Guest House** at Plot No. 937, Street No. 3, Naiwalan, Karol Bagh, New Delhi, comprised of, basement (vacant), ground floor (reception, lobby & office), 1st floor to 3rd floor (05 guest rooms at each floor) (total 15 guest rooms only), was issued FSC by this department vide letter No. F.6/DFS/MS/NDZ/2019/2030 dated 22.10.2019. The premises was re-inspected by the officer concerned of this department on dated 20.01.2025 in the presence of Sh. Rachit Gupta (Director) and found that the guest house have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi fire service Rules 2010 and that the building/premises is fit for occupancy class "**Residential**" (Guest house) (15 guest rooms only upto 3rd floor only) w.e.f 29/01/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 29/01/2025 at New Delhi.

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

- 1 The Commissioner, MCD, Delhi: to ensure the occupancy as detailed above and deviation, if any.
 - 2 **Online application Id 2025010600204 dated 08.01.2025.**
 - 3 The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi.
- : - for information regarding use of basement.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws and use of the basement will only be allowed after permission from MCD. Presently basement is vacant.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/12

INSPECTION REPORT

1. Name & address of the building : Lavista Guest House at 937, Street No. 3, Naiwalan, Karol Bagh, New Delhi.
2. Building is comprised of : B, G+3 upper floors (total 15 guest rooms), Ground (Reception, lobby & office), 1st floor to 3rd floor (05 guest rooms at each floor)
3. Type of Occupancy : Residential (Guest House)
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/NDZ/2019/2030 dated 22.10.2019
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 20.01.2025
8. Name of the Inspecting officers : ADO R.K. Yadav (JKP)
9. Name and designation of officer from the building side : Sh. Rachit Gupta (Director)
10. Year of construction : 2010
11. Applicant's letter No : ID No. 2025010600204 dated 08.01.2025

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	N/A N/A N/A	06 m N/A N/A	N/A N/A N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	01 Nos. 01 Nos.	01 Nos. 01 Nos.	MR MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	0.80 m, old case 0.80 m, old case	1.23 to 1.28 m 1.28 m	MR MR
	c. Protection of Exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	01	01	MR
	e. Width of Corridor	N/A	2.20, 2.05 m	N/A
	f. Door Size	1.0 m	0.89 × 2.08 m	MR, old case
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	30 ACPH 12 ACPH	Exhaust fan Natural Ventilation	MR MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	12 nos. ABC /CO ₂ ISI marked	Provided Provided Provided	MR MR MR

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic Fire Detection, CO detection and Alarming System.			
	• CO Type of detectors	Required	Provided	MR
	• Location of main panel	Ground floor	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement & Stilt	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump			
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 ltrs	5,000 ltrs	MR, old case
15	Exit Signage.	Required	Provided	MR

16 Provision of Lifts.				
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18 Refuge Area.				
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19 Fire Control Room				
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - The building is comprised of Basement (vacant), ground floor (reception, lobby & office), 1st, 2nd, & 3rd floor each having 05 guest rooms respectively (total 15 guest rooms only).

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/NDZ/2019/2030 dated 22.10.2019, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
21/01/2025
Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

~~DO (CD)~~

R.K.
23/1/25

Dy. CFS (NDZ) - on leave

CFS
23/01/2025
Director
23/01/25

ADO/2M